

Minutes

Of the meeting of the:

Strathfield Internal Development Assessment Panel Meeting

Held on:

Friday, 5 June 2020

Commencing at 10:00am Main Building Meeting Room,
65 Homebush Road, Strathfield

TABLE OF CONTENTS

Item	Page No.
IDAP AGENDA ITEMS	
IDAP - Report No. 1 DA2020/01: 31 Rickard Road, Strathfield Lot 27 DP16967	4
IDAP - Report No. 2 DA2020/50 - 149 Coronation Parade, Strathfield South - Lot 6 DP 312813.....	25
IDAP - Report No. 3 2018/115/2 - 31 Boden Avenue, Strathfield - Lot 60 DP 15955	46

The meeting of the Strathfield Internal Development Assessment Panel Meeting was held in the Main Building Meeting Room, 65 Homebush Road, Strathfield on Friday 5 June 2020.

PRESENT

Stephen Clements, Deputy CEO/General Manager Planning, Environment & Urban Services
Kandace Lindeberg, Executive Manager, Landuse Planning and Development
George Andonoski, Specialist Strategic Planner

ALSO PRESENT

Nil

DECLARATIONS OF PECUNIARY INTEREST / CONFLICT OF INTEREST

Nil

TO: Strathfield Internal Development Assessment Panel Meeting - 5 June 2020
REPORT: IDAP – Report No. 1
SUBJECT: DA2020/01: 31 RICKARD ROAD, STRATHFIELD
 LOT 27 DP16967
DA NO. 2020/01

RECOMMENDATION

That Development Application No. 2020/001 for demolition of existing buildings and construction of a two storey dwelling with basement level, in ground swimming pool and boundary fencing at 31 Rickard Road, Strathfield be **APPROVED**, subject to the following conditions:

GENERAL CONDITIONS (GC)

1. APPROVED PLANS AND REFERENCE DOCUMENTATION (GC)

The development, except where modified by a condition(s) of consent, is to be carried out in accordance with the following plans and reference documentation:

Plans affixed with Council's 'Development Consent' stamp relating to Development Consent No. 2020/001:

Drawing No.	Title/Description	Prepared by	Issue / Revision & Date	Date received by Council
DA02	Demolition Plan	Archispectrum	D	1 June 2020
DA03	Proposed Basement Plan	Archispectrum	D	1 June 2020
DA04	Proposed Ground Floor Plan	Archispectrum	D	1 June 2020
DA05	Proposed First Floor Plan	Archispectrum	D	1 June 2020
DA06	Proposed Site and Roof Plan	Archispectrum	D	1 June 2020
DA07	Proposed Elevations	Archispectrum	D	1 June 2020
DA08	Proposed South Elevation and Section A-A Plan	Archispectrum	D	1 June 2020
DA13	Proposed Landscape Plan	Archispectrum	D	1 June 2020
DA14	External Finishes Plan	Archispectrum	D	1 June 2020
DA15	Erosion & Sediment Control Plan	Archispectrum	D	1 June 2020
DA16	Driveway Ramp and Section B-B	Archispectrum	D	1 June 2020
DA21	Boundary Fence Details	Archispectrum	D	1 June 2020
Sheet 1	Driveway Plan	ACE Civil & Hydraulic Engineers	Dated 19 May 2020	20 May 2020
Sheet 1 - 7	Drainage Plan	ACE Civil &	Dated 20	6 January 2020

		Hydraulic Engineers	December 2019	
--	--	---------------------	---------------	--

Reference Documentation affixed with Council's 'Development Consent' stamp relating to Development Consent No. 2020/001:

Title / Description	Prepared by	Issue/Revision & Date	Date received by Council
BASIX	-	Issued 20 December 2019, Cert No.1068055S	6 January 2020
Waste Management Plan	Archispectrum	Issue A – December 2019	6 January 2020
Construction Impact Assessment and Management Plan	George Palmer	18 May 2020	21 May 2020

In the event of any inconsistency, the conditions of this consent shall prevail.

(Reason: To ensure that the form of the development undertaken is in accordance with the determination of Council.)

2. BUILDING HEIGHT - MAXIMUM RL TO BE COMPLIED WITH (GC)

The height of the building measured from Australian Height Datum (AHD) must not exceed Relative Level (RL) 39.12AHD to the roof ridge of the building.

(Reason: To ensure the approved building height is complied with.)

3. CONSTRUCTION HOURS (GC)

No construction or any other work related activities shall be carried out on the site outside the hours of 7.00 am to 5.00 pm Mondays to Fridays and 8am to 1pm Saturdays.

No building activities are to be carried out at any time on a Sunday or public holiday.

Where the development involves the use of jackhammers/rock breakers and the like or other heavy machinery, such equipment may only be used between the hours of 7.00 am - 5.00 pm Monday to Friday only.

(Reason: To maintain amenity to adjoining land owners.)

4. CONSTRUCTION WITHIN BOUNDARIES (GC)

The development including but not limited to footings, walls, roof barges and guttering must be constructed wholly within the boundary of the premises. No portion of the proposed structure shall encroach onto the adjoining properties. Gates must be installed so they do not open onto any footpath or adjoining land.

(Reason: Approved works are to be contained wholly within the subject site.)

5. DEMOLITION – GENERALLY (GC)

Alteration and demolition of the existing building is limited to that documented on the approved plans (by way of notation). No approval is given or implied for removal and/or rebuilding of any portion of the existing building which is not shown to be altered or

demolished.

(Reason: To ensure compliance with the approved development.)

6. **DEMOLITION - SITE SAFETY FENCING (GC)**

Site fencing is to be erected to a minimum height of 1.8m complying with WorkCover Guidelines, to exclude public access to the site, prior to any demolition works occurring and maintained for the duration of the demolition works.

If applicable, a separate Hoarding Application for the erection of an A class (fence type) or B class (overhead type) hoarding/fencing along the street frontage(s) complying with WorkCover requirements must be obtained including:

- payment to Council of a footpath occupancy fee based on the area of footpath to be occupied and Council's Schedule of Fees and Charges before the commencement of work; and
- provision of a Public Risk Insurance Policy with a minimum cover of \$10 million in relation to the occupation of and works within Council's road reserve, for the full duration of the proposed works, must be obtained with a copy provided to Council.

(Reasons: Statutory requirement and health and safety.)

7. **LANDSCAPING - CANOPY TREES IN FRONT AND REAR SETBACK (GC)**

The development is to provide 3 canopy trees within the grounds of the property from 300 litre containers. One (1) canopy tree is to be planted in the rear yard and have a potential mature height of 15 metres. Two (2) canopy trees are to be planted in the front yard and have a potential mature height of 10 metres.

Species shall be selected from Council's Recommended Tree List (Available from Council's website or from the Customer Service Centre). Compliance with this condition is to be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To ensure the landscape character of the locality is maintained.)

8. **ENVIRONMENTAL PROTECTION – TREE (GC)**

All street trees and trees on private property that are protected under Council's controls, shall be retained except where Council's prior written consent has been obtained. The felling, lopping, topping, ringbarking, wilful destruction or removal of any tree/s unless in conformity with this approval or subsequent approval is prohibited.

All healthy trees and shrubs identified for retention on the approved drawings are to be suitably protected in accordance with Section 4, Tree protection measures, and Appendix C Tree Protection Zone Sign, of Australian Standard AS4970 - 2009, Protection of Trees on Development Sites, prior to the commencement of any works (including any demolition and excavation) and maintained for the duration of the works.

In this regard the street tree and all protected trees on or adjacent to the site will be protected as described below;

- i. A Tree Protection (Management) Plan prepared by a AQF Level 5 Arborist is to be available on site at all times prior to the issue of the Constriction Certificate, for all demolition and site works. This Tree Protection

- (Management) Plan must be shown on the demand of Authorised Council staff.
- ii. Protective perimeter fencing must be consistent with AS 4687, using metal fence posts greater than 20mm diameter and solid or chain wire mesh 2 metres in height supported on concrete pads/feet at 2-2.5 metre spacing. Fencing placement should not be closer than 2.5 metres from the trunk of each protected tree, or at a distance as specified by the approved Tree Protection (Management) Plan and approved by Council's Tree Management Officer. Shade cloth is to be used to prevent entry of dust and contaminated liquids into the root protection area.
 - iii. Signs must be placed on the Fencing. These signs must comply with AS1319. The signs must state the purpose of the fencing and the name and contact details of the builder and the appointed AQF Level 5 consultant arborist.
 - iv. Root protection is to be provided in the form of mulching to a depth of 50-100mm, inside of the fenced tree protection zone.
 - v. Ground (Root) Trunk and Branch Protection must comply with the diagram of Figure 4 of AS4970 – 2009. Ground protection within the tree protection zone and drip line should be in the form of heavy steel plates or timber rumble boards over mulch or aggregate. Trunk and branch protection should be to a minimum height of 2 metres and must include measures to protect the tree/s against damage from the movement of trucks, plant equipment and materials at greater heights above ground level.
 - vi. Temporary signs, cables, wires must not be attached to, or suspended, on any street tree or protected tree.
 - vii. Above ground utilities must not be placed within the canopy of an existing protected tree, or create the future need for clearance pruning.
 - viii. Below ground utilities/services must not be located inside the fenced tree protection zone.
 - ix. Scaffolding must not be located in the fenced tree protection zone unless authorised by the approved Tree Protection (Management) Plan and Council's Tree Management Officer
 - x. Council must be notified in writing within 24 hours, for all temporary removal of the tree protection fencing ground (root) trunk and branch protection within the root protection area.
 - xi. Pruning of a street tree is prohibited without the written consent of Council.

(Reason: To ensure the protection of trees to be retained on the site.)

9. MATERIALS – CONSISTENT WITH SUBMITTED SCHEDULE (GC)

All external materials, finishes and colours are to be consistent with the schedule submitted and approved by Council with the development application.

(Reason: To ensure compliance with this consent.)

10. PRINCIPAL CERTIFYING AUTHORITY (PCA) IDENTIFICATION SIGN (GC)

Prior to commencement of any work, signage must be erected in a prominent position on the work site identifying:

- i) The Principal Certifying Authority (PCA) by showing the name, address and telephone number of the PCA;
- ii) The Principal Contractor by showing the Principal Contractor's name, address and telephone number (outside of work hours) for that person; and
- iii) The sign must state that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the work is being carried out, but must be removed when the work has been completed.

This clause does not apply to building work, subdivision work or demolition work that is carried out inside an existing building that does not affect the external walls of the building.

(Reason: Statutory requirement.)

11. **SITE MANAGEMENT (DURING DEMOLITION AND CONSTRUCTION WORKS)**

All of the following are to be satisfied/complied with during demolition, construction and any other site works:

- i) All demolition is to be carried out in accordance with Australian Standard AS 2601-2001.
- ii) Demolition must be carried out by a registered demolition contractor.
- iii) A single entrance is permitted to service the site for demolition and construction. Protection pads are to be installed to the kerb, gutter and nature strip where trucks and vehicles enter the site.
- iv) No blasting is to be carried out at any time during construction of the building.
- v) Care must be taken during demolition/ excavation/ building/ construction to prevent any damage to adjoining buildings.
- vi) Adjoining owner property rights and the need for owner's permission must be observed at all times, including the entering onto land for the purpose of undertaking works.
- vii) Any demolition and excess construction materials are to be recycled wherever practicable.
- viii) The disposal of construction and demolition waste must be in accordance with the requirements of the Protection of the Environment Operations Act 1997.
- ix) All waste on the site is to be stored, handled and disposed of in such a manner as to not create air pollution (including odour), offensive noise or pollution of land and/or water as defined by the Protection of the Environment Operations Act 1997. All excavated material should be removed from the site in an approved manner and be disposed of lawfully to a tip or other authorised disposal area.
- x) All waste must be contained entirely within the site.
- xi) A site plan including temporary waste storage locations, construction material storage areas and vehicular access to and from the site must be included with application.
- xii) Section 143 of the Protection of the Environment Operations Act 1997 requires waste to be transported to a place which can lawfully accept it. All non-recyclable demolition materials are to be disposed of at an approved waste disposal depot in accordance with legislation.
- xiii) Details as to the method and location of disposal of demolition materials (weight dockets, receipts, etc.) should be kept on site as evidence of approved methods of disposal or recycling and must be presented to Council and/or Principal Certifying Authority upon request.
- xiv) All materials on site or being delivered to the site are to generally be contained within the site. The requirements of the Protection of the Environment Operations Act 1997 must be complied with when placing/stockpiling loose material, disposing of concrete waste, or other activities likely to pollute drains or water courses.
- xv) Any materials stored on site must be stored out of view or in such a manner so as not to cause unsightliness when viewed from nearby lands or roadways.
- xvi) Public footways, include nature strips and roadways adjacent to the site must be maintained and cleared of obstructions during construction. No building materials, waste containers or skips may be stored on the road reserve or footpath without

- prior separate approval from Council, including payment of relevant fees.
- xvii) Building operations such as brick-cutting, washing tools or paint brushes, and mixing mortar not be performed on the roadway or public footway or any other locations which could lead to the discharge of materials into the stormwater drainage system.
 - xviii) All site waters during excavation and construction must be contained on site in an approved manner to avoid pollutants entering into waterways or Council's stormwater drainage system.
 - xix) Any work must not prohibit or divert any natural overland flow of water.
 - xx) Toilet facilities for employees must be provided in accordance with WorkCover NSW.

(Reason: To ensure that demolition, building and any other site works are undertaken in accordance with relevant legislation and policy and in a manner which will be non-disruptive to the local area.)

12. **STORMWATER MANAGEMENT PLAN - CERTIFICATION REQUIREMENT (GC)**

A detailed Stormwater Management Plan (SWMP) in line with Council's Stormwater Management Code is to be prepared and certified by an Accredited Civil/Hydraulic Engineer and submitted to the Principal Certifying Authority and Council, prior to the issue of a Construction Certificate. The SWMP is to be based on the approved development as modified by any conditions of consent.

(Reason: To ensure appropriate provision is made for the disposal and management of stormwater generated by the development, and to ensure public infrastructure in Council's care and control is not overloaded.)

13. **SYDNEY WATER - TAP IN™ (GC)**

The approved plans must be submitted to a Sydney Water Tap in™ to determine whether the development application will affect Sydney Water's sewer and water mains, stormwater drains and/or easements, and if further requirements need to be met. The approved plans will be appropriately endorsed. For details please refer to 'Plumbing, building and developing' section of Sydney Water's web site at www.sydneywater.com.au then see 'Building', or telephone 13000 TAP IN (1300 082 746). The Certifying Authority must ensure that a Tap in™ agent has appropriately stamped the plans prior to the issue of the Construction Certificate.

(Reason: Compliance with Sydney Water requirements.)

14. **UTILITIES AND SERVICES - PROTECTION OF (GC)**

Any footings or excavation to be located or undertaken adjacent to Council's stormwater must be designed to address the following requirements:

- i) All footings and excavation must be located wholly within the site and clear of any easement boundaries;
- ii) All footings and excavation must be located a minimum of 1000mm from the centreline of the pipeline or 500mm from the outside of the pipeline, whichever is the greater distance from the centreline; and
- iii) Footings must extend to at least the depth of the invert of the pipeline unless the footings are to be placed on competent bedrock.

If permanent excavation is proposed beneath the obvert of the pipeline, suitable means to protect the excavation and proposed retaining structures from seepage or other water flow from the pipeline and surrounding subsoil, must be provided. The design must be prepared by a qualified practicing Structural/Civil Engineer.

Construction plans must be approved by the appropriate utility's office (e.g. council, Sydney Water Corporation) to demonstrate that the development complies with the utility's requirements.

The applicant must provide written evidence (e.g. compliance certificate, formal advice) of compliance with the requirements of all relevant utility providers (e.g. Water, Energy, Telecommunications, Gas).

(Reason: To ensure protection of Council assets.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF A CONSTRUCTION CERTIFICATE (PCC)

15. BASIX COMMITMENTS (CC)

The approved BASIX Certificate shall be submitted to the Principal Certifying Authority with the application for a Construction Certificate.

Where a change or changes are proposed in the BASIX commitments, the applicant must submit a new BASIX Certificate to the Principal Certifying Authority and Council. If any proposed change in the BASIX commitments is inconsistent with the development consent the applicant will be required to submit a modification to the development consent to Council under Section 4.55 of the Environmental Planning and Assessment Act 1979.

All commitments in the BASIX Certificate must be shown on the plans accompanying the Construction Certificate.

(Reason: Statutory compliance.)

16. BUILDING CODE OF AUSTRALIA - COMPLIANCE WITH (CC)

All architectural drawings, specifications and related documentation shall comply with the Building Code of Australia (BCA). All work must be carried out in accordance with the requirements of the Building Code of Australia (BCA).

In the case of residential building work for which the Home Building Act 1989 requires there to be a contract of insurance in force in accordance with Part 6 of that Act, such a contract of insurance is to be in force before any building work authorised to be carried out by the consent commences.

Details demonstrating compliance with this condition are to be submitted to the Principle Certifying Authority, prior to issue of the Construction Certificate.

(Reason: This is a 'prescribed' condition under clause 98(1) of the Environmental Planning and Assessment Regulation 2000.)

17. CAR PARKING - BASEMENT CAR PARKING REQUIREMENTS (CC)

Details demonstrating compliance with the following is to be submitted to the Principal Certifying Authority, prior to issue of the Construction Certificate:

- i) Minimal internal clearance of the basement is 2.2m in accordance with BCA requirements.
- ii) Driveways shall comply with Australian/New Zealand Standard AS/NZS 2890.1:2004 - Parking facilities - Off-street car parking and achieve a maximum gradient of 1:4.

- iii) Basement entries and ramps/driveways within the property are to be no more than 3.5m wide.
- iv) Provision of pump-out systems and stormwater prevention shall be in accordance with Council's Stormwater Management Guide.

(Reason: To ensure suitable development.)

18. CAR PARKING - VEHICULAR ACCESS RAMPS (CC)

Vehicular access ramps shall comply with the provisions of AS/NZS 2890.1:2004 and Council SCDCP. Plans to be submitted shall contain the following details:

- i) (Other sub-conditions imposed by development engineer)
- ii) A minimum 1mx1m splay shall be provided at the vehicular access driveway on both sides of driveway along the property boundary, to maintain sight distances for pedestrians and motorists. The areas should be kept clear from obstructions and only allow ground cover landscaping, as per Council SCDCP Part A Clause 5.2.4.
- iii) Certification that the design complies with AS/NZS 2890.1:2004 and Council SCDCP by a Qualified Engineer.

The certification referred to in (iii) above shall be submitted to the Principal Certifying Authority prior to the issue of a Construction Certificate (for the design) and to the Principal Certifying Authority prior to the issue of any Occupation Certificate for the 'as-built works'.

(Reason: To ensure adequate vehicular access can be achieved.)

19. CAR PARKING - COMPLIANCE WITH AS/NZS 2890.1:2004 (CC)

Car parking dimensions must comply with the Australian/New Zealand Standard AS/NZS 2890.1:2004 - Parking facilities - Off-street car parking. Details demonstrating compliance are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To ensure compliance with Australian Standards relating to parking of vehicles.)

20. CAR PARKING - VEHICULAR CROSSING WIDTH AT PROPERTY BOUNDARY (CC)

Vehicular crossings are to have a maximum width of 3m at the property boundary. Details demonstrating compliance are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

The vehicular crossing (and all associated excavation works) must not be constructed closer than 2 metres from a retained protected street tree.

(Reason: Compliance with SCDCP 2005.)

21. COMMENCEMENT OF WORKS (NO WORKS UNTIL A CC IS OBTAINED)

Building work, demolition or excavation must not be carried out until a Construction Certificate has been issued by either Strathfield Council or a Principal Certifying Authority.

Demolition of any part of a building triggers 'commencement of erection of building' pursuant of section 4.19 of the EP&A Act 1979. Accordingly, demolition works must not commence until a Construction Certificate has been issued, a Principal Certifying Authority has been appointed and a Notice of Commencement has been issued.

(Reason: To ensure compliance with statutory provisions.)

22. CONSTRUCTION AND ENVIRONMENTAL MANAGEMENT PLAN (CC)

The applicant must prepare and submit a Construction and Environmental Management Plan (CEMP) to the Principal Certifying Authority, including:

- i) Detailed information on any approvals required from other authorities prior to or during construction.
- ii) Traffic management, including details of:
 - ingress and egress of vehicles to the site;
 - management of loading and unloading of materials;
 - the location of heavy vehicle parking off-site; and
 - designated routes for vehicles to the site.
- iii) The proposed areas within the site to be used for a builder's site office and amenities, the storage of excavated material, construction materials and waste containers during the construction period.
- iv) Erosion and sediment control, detailing measures and procedures consistent with the requirements of Council's guidelines for managing stormwater, including:
 - the collection and treatment of stormwater and wastewater generated on site prior to discharge; and
 - procedures to prevent run-off of solid material and waste from the site.
- v) Waste management, including:
 - details of the types and estimated volumes of waste materials that will be generated;
 - procedures for maximising reuse and recycling of construction materials; and
 - details of the off-site disposal or recycling facilities for construction waste.
- vi) Dust control, outlining measures to minimise the generation and off-site transmission of dust and fine particles, such as watering or damp cloth fences.
- vii) A soil and water management plan, which includes:
 - measures to minimise the area of soils exposed at any one time and conserve top soil;
 - identification and protection of proposed stockpile locations;
 - preservation of existing vegetation and revegetation;
 - measures to prevent soil, sand, sediments leaving the site in an uncontrolled manner;
 - measures to control surface water flows through the site in a manner that diverts clean run-off around disturbed areas, minimises slope gradient and flow distance within disturbed areas, ensures surface run-off occurs at non-erodible velocities, and ensures disturbed areas are promptly rehabilitated;
 - details of sediment and erosion control measures in place before work commences;
 - measures to ensure materials are not tracked onto the road by vehicles entering or leaving the site; and
 - details of drainage to protect and drain the site during works.
- viii) Asbestos management procedures:
 - Anyone who removes, repairs or disturbs bonded or a friable asbestos material must hold a current removal licence from Workcover NSW holding either a Friable (Class A) or a Non- Friable (Class B) Asbestos Removal License which ever applies and a current WorkCover Demolition License where works involve demolition. To find a licensed asbestos removalist please see www.workcover.nsw.gov.au
 - Removal of asbestos by a person who does not hold a Class A or Class B asbestos removal license is permitted if the asbestos being removed is 10m² or less of non-friable asbestos (approximately the size of a small bathroom).

Friable asbestos materials must only be removed by a person who holds a current Class A asbestos license.

- Before starting work, a work site-specific permit approving each asbestos project must be obtained from WorkCover NSW. A permit will not be granted without a current WorkCover licence. All removal, repair or disturbance of or to asbestos material must comply with the following:
 - The Work Health and Safety Act 2011;
 - The Work Health and Safety Regulation 2011;
 - How to Safely Remove Asbestos Code of Practice – WorkCover 2011; and
 - Safe Work Australia Code of Practice for the Management and Control of Asbestos in the Workplace.
- Following completion of asbestos removal works undertaken by a licensed asbestos removalist re-occupation of a workplace must not occur until an independent and suitably licensed asbestos removalist undertakes a clearance inspection and issues a clearance certificate.
- The developer or demolition contractor must notify adjoining residents at least two (2) working days (i.e. Monday to Friday exclusive of public holidays) prior to the commencement of asbestos removal works. Notification is to include, at a minimum:
 - the date and time when asbestos removal works will commence;
 - the name, address and business hours contact telephone number of the demolisher, contractor and/or developer;
 - the full name and license number of the asbestos removalist/s; and
 - the telephone number of WorkCover's Hotline 13 10 50
 - warning signs informing all people nearby that asbestos removal work is taking place in the area. Signs should be placed at all of the main entry points to the asbestos removal work area where asbestos is present. These signs should be weatherproof, constructed of light-weight material and adequately secured so they remain in prominent locations. The signs should be in accordance with AS 1319-1994 Safety signs for the occupational environment for size, illumination, location and maintenance; and
 - appropriate barricades installed as appropriate to prevent public access and prevent the escape of asbestos fibres. Barricades must be installed prior to the commencement of asbestos removal works and remain in place until works are completed.

(Reason: Safety, amenity and protection of public infrastructure and the environment.)

23. **COUNCIL PERMITS – FOR ALL ACTIVITIES ON COUNCIL LAND (CC)**

Works Permit

(as per Section 68 of the Local Government Act 1993 and Section 138 and 139 of the Roads Act 1993)

A Works Permit is required for construction of a vehicular crossing (driveway), new stormwater down pipe connection to kerb and gutter, new footpath and/or stormwater connection. A Works Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Standing Plant Permit

This permit must be applied for where it is intended to park a concrete pump, crane or other plant on the roadway or footpath. A Standing Plant Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure

Permit is not required for standing plant.

Skip Bin Permit

This permit must be applied for if you intend to place a skip bin on the roadway or footpath. A Skip Bin Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Temporary Full or Part Road Closure Permit

This permit must be applied for if you require a full or a part road closure to take place to assist in your construction works. Please use the Works Permit Application Form, which is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Hoarding/Fencing Permit

This permit must be applied for if you intend to erect a Class A (fence type) or Class B (overhead type) hoarding/fencing along the street frontage(s). A Hoarding Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Work Zone Permit

This permit must be applied for if you require permanent parking along the kerbside at the front of the site during construction works. A Work Zone Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Ground Anchoring Permit

This permit must be applied for, for the installation of ground anchors under Council's footway/road reserve. It does not cover ground anchors under private properties. A separate approval is required to be obtained from Roads and Maritime Services (RMS) if it is proposed to install ground anchors under a State or Classified Regional Road (please refer to the end of this application form for more information).

(Reason: Council requirement.)

24. DILAPIDATION REPORT - PRE-COMMENCEMENT (CC)

Subject to access being granted, a pre-commencement Dilapidation Report is to be undertaken on all adjoining properties, which in the opinion of a suitably qualified engineer, could be potentially affected by the construction of the project. The Dilapidation Report shall be carried out prior to the issue of a Construction Certificate.

The Dilapidation Report is to be prepared by a suitably Qualified Engineer with current Corporate Membership with the Institution of Engineers, Australia or Geotechnical Practitioner. The report shall include a photographic survey of adjoining properties detailing the physical condition of those properties, both internally and externally, including walls, ceilings, roof, structural members and other such items.

If access for undertaking the dilapidation survey is denied by an adjoining owner, the applicant must demonstrate, in writing, to Council's satisfaction attempts have been made to obtain access and/or advise the affected property owner of the reason for the survey and these attempts have been unsuccessful. Written concurrence must be obtained from Council in such circumstances.

The Report shall cover structural and geotechnical factors likely to arise from the development. A copy of this Report shall be submitted to Council as a record. The person having the benefit of the development consent must, at their own cost, rectify any damage caused to other properties during the construction of the project.

(Reason: To ensure no damage to adjoining properties occurs.)

25. **EXCAVATION - AFFECTING ADJOINING LAND (CC)**

If an excavation associated with the approved development extends below the level of the base of the footings of a building on an adjoining allotment of land, the person having the benefit of the development consent must, at the person's own expense, comply with the requirements of clause 98E of the Environmental Planning and Assessment Regulation 2000, including:

- i) Protect and support the adjoining premises from possible damage from the excavation, and
- ii) Where necessary, underpin the adjoining premises to prevent any such damage.

The condition referred to in subclause (i) does not apply if the person having the benefit of the development consent owns the adjoining land or the owner of the adjoining land has given consent in writing to that condition not applying. Details shall be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Structural safety.)

26. **LANDSCAPING - MAINTENANCE STRATEGY (CC)**

To ensure the survival of landscaping following works, a landscape maintenance strategy for the owner/occupier to administer over a 12 month establishment period following the issue of the Occupation Certificate shall be prepared and provided to the satisfaction of the Principal Certifying Authority with the Construction Certificate application. The strategy is to address maintenance issues such as, but not limited to plant survival, irrigation, soil testing, weeding, staking, fertilizing, remedial pruning and plant replacement.

(Reason: Ensure landscape survival.)

27. **PRIVACY - OBSCURE GLAZING IN WET AREAS (CC)**

All bathroom, ensuite and toilet windows shall be installed with obscure glazing. Plans shall be notated accordingly and details demonstrating compliance submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Privacy amenity.)

28. **SECTION 7.12 CONTRIBUTION PAYMENT - INDIRECT CONTRIBUTIONS PLAN) (CC)**

In accordance with the provisions of Section 7.13 of the Environmental Planning and Assessment Act 1979 and the Strathfield Indirect Development Contributions Plan 2010-2030, a contribution in the form of cash, cheque or credit card (financial transaction fee applies) shall be paid to Council for the following purposes:

Local Amenity Improvement Levy	\$11,839.88
--------------------------------	--------------------

The total amount of the contribution is valid as at the date of determination and is subject to quarterly indexation. The amount of the contribution under this condition shall be indexed in

accordance with clause 4.12 of the Strathfield Indirect Development Contributions Plan 2010-2030.

Contributions must be receipted by Council and submitted to the Accredited Certifier, prior to the issue of any Construction Certificate.

A copy of this condition is to be presented to Council's Customer Service Centre when paying the contribution so that it can be recalculated.

Note: A copy of Strathfield Council's Section 7.12 Indirect Development Contributions Plan may be downloaded from Council's website.

(Reason: To enable the provision of public amenities and services required/anticipated as a consequence of increased demand resulting from the development.)

29. **SECURITY PAYMENT – DAMAGE DEPOSIT FOR COUNCIL INFRASTRUCTURE (CC)**

A security (damage deposit) of **\$15,000.00** (calculated in accordance with Council's adopted Fees and Charges) shall be paid to Council, prior to the issue of a Construction Certificate.

The deposit is required as security against any damage to Council property during works on the site. The applicant must bear the cost of all restoration works to Council's property damaged during the course of this development. All building work must be carried out in accordance with the Building Code of Australia.

Payment may be accepted in the form of cash, bank guarantee, cheque or credit card (financial transactions fees apply). Note: Additional fees apply for the lodgement of a bank guarantee in lieu of cash bond applies in accordance with Council's adopted Fees and Charges.

Any costs associated with works necessary to be carried out to rectify any damages caused by the development, shall be deducted from the Damage Deposit.

Note: Should Council property adjoining the site be defective e.g. cracked footpath, broken kerb etc., this should be reported in writing, or by photographic record, submitted to Council at least seven (7) days prior to the commencement of any work on site. This documentation will be used to resolve any dispute over damage to infrastructure. It is in the applicant's interest for it to be as full and detailed as possible.

The damage deposit shall be refunded upon completion of all works upon receipt of a Final Occupation Certificate stage and inspection by Council.

(Reason: Protection of Council infrastructure.)

30. **STORMWATER - RAINWATER RE-USE (CC)**

A rainwater re-use system shall be provided in accordance with either the BASIX minimum requirements, any relevant Council Rainwater Policy and/or specification of the management of stormwater, whichever is applicable. A detailed stormwater plan showing the proposed re-use system shall be submitted to and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Compliance and amenity.)

31. SWIMMING POOLS / SPAS (CONSTRUCTION OF)

The approved swimming pool/spa must comply with all relevant legislation including:

- i) Swimming Pools Amendment Act 1992 (as amended);
- ii) Swimming Pools Regulations 2008; and
- iii) Australian Standard AS1926.1-2012 – Safety Barriers for Swimming Pools.

Details demonstrating compliance with this condition shall be demonstrated to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Safety and statutory compliance.)

29. SWIMMING POOLS / SPAS - MECHANICAL PLANT ENCLOSURE (CC)

Any mechanical plant associated with the swimming pool and spa shall be acoustically treated to comply with the Protection of the Environment Operations Act 1997. Details are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To ensure the acoustic amenity of the neighbouring residents.)

33. TREE BONDS (CC)

A tree bond of **\$40,000.00** (calculated in accordance with Council's adopted Fees and Charges) shall be paid to Council, prior to the issue of a Construction Certificate.

The deposit is required as security against any damage to existing trees to be retained on Council's road reserve, during works on the site. The applicant must bear the cost of all restoration works to Council's property damaged during the course of this development.

Payment may be accepted in the form of cash, bank guarantee, cheque or credit card (financial transactions fees apply). Note: Additional fees apply for the lodgement of a bank guarantee in lieu of cash bond applies in accordance with Council's adopted Fees and Charges.

A refund of the Tree Bond must be made in writing.

Tree Bonds may be forfeited if a tree is dead, made dangerous or has been terminally damaged, or will be held until tree/s have fully recovered from the construction damage or were replacement/planted trees have become fully established and are over 6 metres in height.

(Reason: To ensure the protection of trees to be retained on Council's Road Reserve.)

34. VENTILATION SYSTEMS – MECHANICAL (CC)

The mechanical ventilation system is to comply with the following:

- i) The Building Code of Australia;
- ii) Protection of the Environment Operations Act 1997; and
- iii) Australian Standard AS1668-1991.

In addition, odour control measures, such as activated carbon or catalytic oxidisers, must be used to treat ventilation gases prior to discharge. The method of odour control must be designed by a suitably qualified mechanical ventilation engineer.

Details demonstrating compliance with the above are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To ensure the mechanical ventilation system complies with the relevant requirements/standards.)

35. WATER SUSTAINABILITY – GENERALLY (CC)

Water collected in the rainwater tank must comprise roof water only and not surface water. Water from the rainwater tank must only be used for following purposes and not for human consumption:

- i) Toilet flushing;
- ii) Clothes washing;
- iii) Garden irrigation;
- iv) Car washing and similar outdoor uses;
- v) Filling swimming pools, spa pools and ornamental ponds; and
- vi) Fire fighting.

(Reason: To promote sustainable water management practice.)

36. WATER HEATING SYSTEMS - LOCATION OF (CC)

Water heating systems shall be located so as not to be visible from public places and the ground level of adjoining properties. Details (type and location) of the water heaters shall be submitted to and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To maintain streetscape character.)

37. WORKS ZONE - APPROVAL BY COUNCIL'S TRAFFIC COMMITTEE (CC)

An application for a 'Works Zone' must be submitted to and approved by the Strathfield Council Traffic Committee prior to the commencement of any site work (including demolition).

The suitability of the proposed length and duration of the Works Zone is to be demonstrated in the application for the Works Zone. The application for the Works Zone must be submitted to Council at least six (6) weeks prior to the commencement of work on the site to allow for assessment and tabling of agenda for the Strathfield Council Traffic Committee.

The requirement for a Works Zone may be varied or waived only if it can be demonstrated in the Construction Traffic Management Plan (to the satisfaction of Council) that all construction related activities (including all loading and unloading operations) can and will be undertaken wholly within the site. The written approval of Council must be obtained to provide a Works Zone or to waive the requirement to provide a Works Zone prior to the commencement of any site work.

(Reason: Council requirement.)

CONDITIONS TO BE SATISFIED PRIOR TO THE COMMENCEMENT OF WORKS (PCW)

38. APPOINTMENT OF A PRINCIPAL CERTIFYING AUTHORITY (PCA) (CW)

No work shall commence in connection with this Development Consent until:

- i) A construction certificate for the building work has been issued by the consent authority or a Principal Certifying Authority.
- ii) The person having the benefit of the development consent has appointed a principal certifying authority for the building work, and notified the principal certifying authority that the person will carry out the building work as an owner/builder, if that is the case.
- iii) The principal certifying authority has, no later than 2 days before the building work commences:
 - notified the Council of his or her appointment, and
 - notified the person having the benefit of the development consent of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- iv) The person having the benefit of the development consent, if not carrying out the work as an owner-builder, has:
 - appointed a principal contractor for the building work who must be the holder of a contractor licence if any residential building work is involved;
 - notified the principal certifying authority of such appointment; and
 - unless that person is the principal contractor, notified the principal contractor of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- v) The person having the benefit of the development consent has given at least 2 days' notice to the Council of the person's intention to commence the erection of the building.

Note: If the principal certifying authority is the Council, the nomination will be subject to the payment of a fee for the service to cover the cost of undertaking all necessary inspections and the issue of the appropriate certificates.

Under the Environment Planning and Assessment (Quality of Construction) Act, 2003, a sign must be erected in a prominent position on the work site showing the name, address and telephone number of the principal certifying authority; the name of the principal contractor (if any) for the building work and a telephone number at which that person may be contacted outside working hours. That sign must also state that unauthorised entry is prohibited. The sign must not be removed until all work has been completed.

(Reason: Statutory requirement.)

39. HOME BUILDING COMPENSATION FUND (CW)

No residential building work within the meaning of the Home Building Act 1989 may commence until:

- i) A contract of insurance in accordance with Part 6 of the Home Building Act 1989 is entered into and in force, where such a contract is required under that Act (this is a prescribed condition of consent pursuant to clause 981(b) Environmental Planning and Assessment Regulation 2000.
- ii) The PCA is satisfied that the principal contractor for the work is the holder of the appropriate licence and is covered by the appropriate insurance, in each case if required by the Home Building Act 1989 (unless the work is to be carried out by an owner-builder).
- iii) If the work is to be carried out by an owner builder, that the owner builder is the holder of any owner -builder permit required under the Home Building Act 1989.
- iv) Written notice of the following information has been provided to Council (this is a prescribed condition of consent pursuant to clause 98B of the Environmental Planning and Assessment Regulation 2000):

- In the case of work for which a principal contractor is required to be appointed:
- the name and licence number of the principal contractor; and
- the name of the insurer by which the work is insured under Part 6 of the Home Building Act 1989.

In the case of work to be done by an owner-builder:

- the name of the owner-builder; and
- if the owner-builder is required to hold an owner-builder permit under the Home Building Act 1989, the number of the owner-builder permits.

Where Council is not the PCA, the PCA is responsible for notifying Council of the above matters.

Note: Where arrangements for doing residential building work change while the work is in progress so that the above information becomes out of date, the PCA (where not the Council) must provide Council with written notice of the updated information.

(Reason: Statutory requirement.)

40. NOTICE OF COMMENCEMENT (CW)

No work shall commence until the following details are submitted to Council:

- i) a Notice of Commencement (form will be attached with issue of a Construction Certificate or available from our website) within two (2) days of the date on which it is proposed to commence works associated with the Development Consent;
- ii) details of the appointment of a Principal Certifying Authority (either Council or another Principal Certifying Authority); and
- iii) details of the name, address and licence details of the Builder.

(Reason: Statutory requirement.)

CONDITIONS TO BE SATISFIED DURING DEMOLITION AND BUILDING WORKS (DBW)

41. FILL MATERIAL (DW)

The only waste derived material which may be received at the development site is:

- i) Virgin excavated material (within the meaning of the Protection of the Environment Operations Act 1997), and
- ii) any other waste-derived material the subject of a resource recovery exemption under cl.51A of the Protection of the Environment Operations (Waste) Regulation 2005 that is permitted to be used as fill material.

Any (b)-type material received at the development site must be accompanied by documentation certifying by an appropriately qualified environmental consultant the materials compliance with the exemption conditions; and this documentation must be provided to the Principal Certifying Authority on request.

(Reason: To ensure imported fill is of an acceptable standard for environmental protection purposes.)

42. OBSTRUCTION OF PUBLIC WAY NOT PERMITTED DURING WORKS (DW)

The public way must not be obstructed by any materials, vehicles, refuse, skips or the like, under any circumstances, without the prior approval of Council.

(Reason: To maintain public access and safety.)

43. PUBLIC INFRASTRUCTURE AND SERVICES (DW)

The applicant must comply with the requirements (including financial costs) of any relevant utility provider (e.g. Energy Australia, Sydney Water, Telstra, RMS, Council etc.) in relation to any connections, works, repairs, relocation, replacements and/or adjustments to public infrastructure or services affected by the development.

(Reason: To maintain public infrastructure and/or services.)

44. SURVEY REPORT OF APPROVED LEVELS DURING AND POST CONSTRUCTION (DW)

A Survey Certificate to Australian Height Datum shall be prepared by a Registered Surveyor as follows:

- i) At the completion of the first structural floor level prior to the pouring of concrete indicating the level of that floor and the relationship of the building to the boundaries.
- ii) At the completed height of the building, prior to the placement of concrete form work, or the laying of roofing materials.
- iii) At the completion of the development.

Progress certificates in response to points (1) through to (3) shall be provided to the Principal Certifying Authority at the time of carrying out relevant progress inspections. Under no circumstances is work allowed to proceed until such survey information is submitted to and approved by the Principal Certifying Authority.

(Reason: To ensure compliance with the approved plans.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF AN OCCUPATION CERTIFICATE (POC)

45. CAR PARKING - SURPLUS VEHICULAR CROSSINGS (OC)

All surplus vehicular crossings and/or kerb laybacks must be removed and reinstated with concrete kerb and gutter or to the existing edging profile as specified by Council. The nature strip is to be restored and the footpath area reinstated. All of the above are to be restored to the satisfaction of Council's Engineer and at full cost to the applicant, prior to the issue of any Occupation Certificate.

(Reason: Maintenance of public infrastructure.)

46. ENGINEERING WORKS (CERTIFICATION OF)

Prior to occupation of the premises, a Work As Executed (WAE) Plan of all engineering and/or drainage works is to be submitted to the Principal Certifying Authority. The WAE Plan is to be certified by an Accredited Civil/Hydraulic Engineer demonstrating that:

- i) The stormwater drainage system; and/or
- ii) The car parking arrangement and area; and/or
- iii) Any related footpath crossing works; and/or
- iv) The proposed basement pump and well system; and/or
- v) The proposed driveway and layback; and/or
- vi) Any other civil works

have been constructed in accordance with the approved plans and any relevant Standards

and Council policies/specifications.

For major works, such as subdivisions, works within the road reserve (requiring separate S138 approval) and as where specified by Council, a Part 4A Certificate will be required. It is strongly recommended that an Engineer supervise all engineering related works.

Where Council is not the Principal Certifying Authority, an electronic copy of the above documents is to be provided to Council, prior to the issue of any Occupation Certificate.

(Reason: Asset management.)

47. OCCUPATION OF BUILDING (OC)

A person must not commence occupation or use (or change of use where an existing building) of the whole or any part of a new building (within the meaning of section 109H (4) of the Act) unless an Interim Occupation Certificate or Final Occupation Certificate has been issued in relation to the building or part.

The Principal Certifying Authority is required to be satisfied, amongst other things, that:

- i) All required inspections (including each applicable mandatory critical stage inspection) have been carried out; and
- ii) Any preconditions to the issue of the certificate required by a development consent have been met.

Note: New building includes an altered portion of, or an extension to, an existing building.

(Reason: Statutory requirement.)

48. RAINWATER TANKS (OC)

Rainwater tanks must be installed on residential properties by a suitably qualified and licensed plumber and in accordance with the following:

- i) Australian/New Zealand Standard AS/NZS 3500:2003;
- ii) NSW Code of Practice Plumbing and Drainage, 2006 produced by Committee on Uniformity of Plumbing and Drainage Regulations in NSW (CUPDR); and
- iii) Council's rainwater tank policy.

Details demonstrating compliance with this condition are to be submitted to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To protect public health and amenity.)

49. STORMWATER - CERTIFICATION OF THE CONSTRUCTED DRAINAGE SYSTEM (OC)

The constructed stormwater system shall be certified by a suitably qualified person, in accordance with Council's Stormwater Management Code, prior to the issue of any Occupation Certificate.

(Reason: Adequate stormwater management.)

50. SWIMMING POOLS / SPAS - REGISTRATION AND REQUIREMENTS (OC)

The approved swimming pool/spa must comply with all relevant legislation including:

- i) Swimming Pools Amendment Act 1992 (as amended);
- ii) Swimming Pools Regulations 2008; and
- iii) Australian Standard AS1926.1-2012 – Safety Barriers for Swimming Pools.

Swimming pool owners must register their swimming pool or spa on the NSW Swimming Pool Register. A copy of a valid certificate of compliance or relevant occupation certificate must be attached to new residential tenancy agreements to rent property with a swimming pool or spa pool. Note: This requirement does not apply to a lot in strata or community title schemes with more than two lots.

A copy of a valid certificate of compliance or relevant occupation certificate must be attached to new residential tenancy agreements to rent property with a swimming pool or spa pool. Note: This requirement does not apply to a lot in strata or community title schemes with more than two lots; or for any off the plan contacts.

Details demonstrating compliance with this condition shall be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: Safety and statutory compliance.)

RESOLUTION

The application be **APPROVED** subject to the recommended conditions and the amendment to Conditions 2 and 24 as follows:

2. BUILDING HEIGHT - MAXIMUM RL TO BE COMPLIED WITH (GC)

The height of the building measured from Australian Height Datum (AHD) must not exceed Relative Level (RL) 24.45AHD to the roof ridge of the building.

(Reason: To ensure the approved building height is complied with.)

24. DILAPIDATION REPORT - PRE-COMMENCEMENT (CC)

Subject to access being granted, a pre-commencement Dilapidation Report is to be undertaken on all adjoining properties, which in the opinion of a suitably qualified engineer, could be potentially affected by the construction of the project. The Dilapidation Report shall be carried out prior to the issue of a Construction Certificate.

The Dilapidation Report is to be prepared by a suitably Qualified Engineer with current Corporate Membership with the Institution of Engineers, Australia or Geotechnical Practitioner. The report shall include a photographic survey of adjoining properties including No.33 Rickard Road detailing the physical condition of those properties, both internally and externally, including walls, ceilings, roof, structural members and other such items.

If access for undertaking the dilapidation survey is denied by an adjoining owner, the applicant must demonstrate, in writing, to Council's satisfaction attempts have been made to obtain access and/or advise the affected property owner of the reason for the survey and these attempts have been unsuccessful. Written concurrence must be obtained from Council in such circumstances.

FOR: S. Clements, K. Lindeberg, G. Andonoski

AGAINST: nil

**** End Minutes - Report No. 1****

TO: Strathfield Internal Development Assessment Panel Meeting - 5 June 2020
REPORT: IDAP – Report No. 2
SUBJECT: DA2020/50 - 149 CORONATION PARADE, STRATHFIELD SOUTH - LOT 6 DP 312813
DA NO. DA2020/50

RECOMMENDATION

That Development Application No. DA2020/50 for demolition of the existing structure and construction of a new two (2) storey split level dwelling, swimming pool and front fence at 149 Coronation Parade, Strathfield South be **APPROVED**, subject to the following conditions:

SPECIAL CONDITIONS (SC)

1. EXCAVATION LIMITED TO THE BUILDING FOOTPRINT (SC)

The natural ground levels of any areas beyond the footprint of the new dwelling must be retained and unchanged. No excavation must be undertaken beyond the footprint of the new dwelling including areas within the side setback and rear yard. This excludes any excavation required for the swimming pool.

(Reason: To minimise excavation to reduce disturbance to natural ground level particularly adjacent to site boundaries, ensure groundwater tables are maintained and impacts on overland flow/drainage are minimised.)

GENERAL CONDITIONS (GC)

2. APPROVED PLANS AND REFERENCE DOCUMENTATION (GC)

The development, except where modified by a condition(s) of consent, is to be carried out in accordance with the following plans and reference documentation:

Plans affixed with Council's 'Development Consent' stamp relating to Development Consent No. DA2020/50:

Drawing No.	Title/Description	Prepared by	Issue / Revision & Date	Date received by Council
Sheet 01	Upper Ground Level Lower Ground Level Calculation Sheet	Vision Group Architects	Issue B April 2020	21 May 2020
Sheet 02	Roof Site Plan First Floor Plan	Vision Group Architects	Issue B April 2020	21 May 2020
Sheet 03	Elevations Sections Finishes Schedule	Vision Group Architects	Issue B April 2020	21 May 2020
D1	Details, Notes & Legend	NY Civil Engineering	Issue B 30 April 2020	21 May 2020
D2	Basement Plan	NY Civil Engineering	Issue B 30 April 2020	21 May 2020
D3	Stormwater Management Plan	NY Civil Engineering	Issue B 30 April 2020	21 May 2020
D4	Roof Plan	NY Civil Engineering	Issue B 30 April 2020	21 May 2020

D5	Stormwater Details	NY Civil Engineering	Issue B 30 April 2020	21 May 2020
D6	Absorption Trench Details	NY Civil Engineering	Issue B 30 April 2020	21 May 2020
D7	Sediment Control Plan	NY Civil Engineering	Issue B 30 April 2020	21 May 2020
D8	Sediment Control Details	NY Civil Engineering	Issue B 30 April 2020	21 May 2020
L-01 B	Site Plans/Calculations	Site Design + Studios	Issue B 4 March 2020	17 March 2020
L-02 B	Detailed Plan	Site Design + Studios	Issue B 4 March 2020	17 March 2020
L-03 B	Planting Details	Site Design + Studios	Issue B 4 March 2020	17 March 2020
L-04 B	Existing Tree	Site Design + Studios	Issue B 4 March 2020	17 March 2020
L-05 B	Notes	Site Design + Studios	Issue B 4 March 2020	17 March 2020
L-06 B	Specification	Site Design + Studios	Issue B 4 March 2020	17 March 2020

Reference Documentation affixed with Council's 'Development Consent' stamp relating to Development Consent No.DA2020/50:

Title / Description	Prepared by	Issue/Revision & Date	Date received by Council
BASIX Certificate Certificate No. 1085068S	Greenworld Architectural Drafting	10 March 2020	17 March 2020
NAHERS Certificate Certificate No. 0004657441	Greenworld Architectural Drafting	10 March 2020	17 March 2020
Waste Management Plan	Vision Group Architects	-	17 March 2020
Acid Sulfate Soil Assessment	GeoEnviro Consultancy Pty Ltd	21 May 2020	21 May 2020

In the event of any inconsistency, the conditions of this consent shall prevail.

(Reason: To ensure that the form of the development undertaken is in accordance with the determination of Council.)

3. CONSTRUCTION HOURS (GC)

No construction or any other work related activities shall be carried out on the site outside the hours of 7.00 am to 5.00 pm Mondays to Fridays and 8am to 1pm Saturdays.

No building activities are to be carried out at any time on a Sunday or public holiday.

Where the development involves the use of jackhammers/rock breakers and the like or other heavy machinery, such equipment may only be used between the hours of 7.00 am - 5.00 pm Monday to Friday only.

(Reason: To maintain amenity to adjoining land owners.)

4. CONSTRUCTION WITHIN BOUNDARIES (GC)

The development including but not limited to footings, walls, roof barges and guttering must be constructed wholly within the boundary of the premises. No portion of the proposed structure shall encroach onto the adjoining properties. Gates must be installed so they do not open onto any footpath or adjoining land.

(Reason: Approved works are to be contained wholly within the subject site.)

5. DEMOLITION – GENERALLY (GC)

Alteration and demolition of the existing building is limited to that documented on the approved plans (by way of notation). No approval is given or implied for removal and/or rebuilding of any portion of the existing building which is not shown to be altered or demolished.

(Reason: To ensure compliance with the approved development.)

6. DEMOLITION - SITE SAFETY FENCING (GC)

Site fencing is to be erected to a minimum height of 1.8m complying with WorkCover Guidelines, to exclude public access to the site, prior to any demolition works occurring and maintained for the duration of the demolition works.

If applicable, a separate Hoarding Application for the erection of an A class (fence type) or B class (overhead type) hoarding/fencing along the street frontage(s) complying with WorkCover requirements must be obtained including:

- payment to Council of a footpath occupancy fee based on the area of footpath to be occupied and Council's Schedule of Fees and Charges before the commencement of work; and
- provision of a Public Risk Insurance Policy with a minimum cover of \$10 million in relation to the occupation of and works within Council's road reserve, for the full duration of the proposed works, must be obtained with a copy provided to Council.

(Reasons: Statutory requirement and health and safety.)

7. LANDSCAPING ADJACENT SWIMMING POOLS/SPAS (GC)

A minimum one (1) metre wide landscape strip is to be provided between the swimming pool and adjacent common boundaries. The landscape strip is to be planted with a continuous row of evergreen shrubs of a minimum five (5) litre container size and capable of achieving a minimum mature height of three (3) metres. Details of the selected plants shall be submitted to and approved by the Principal Certifying Authority. Compliance with this condition shall be certified by the Principal Certifying Authority, prior to occupation of the premises.

(Reason: Privacy amenity of adjoining properties.)

8. LANDSCAPING - CANOPY TREES IN FRONT SETBACK AND REAR YARD (GC)

New development shall provide canopy trees within the front setback adjacent the front boundary and within the rear yard of the new dwelling. New canopy trees shall be at least three (3) metres high at the time of planting and capable of reaching a mature height of 10m.

Species shall be selected from Council's Recommended Tree List (Available from Council's website or from the Customer Service Centre). Compliance with this condition is to be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To ensure the landscape character of the locality is maintained.)

9. ENVIRONMENTAL PROTECTION – TREE (GC)

All street trees and trees on private property that are protected under Council's controls, shall be retained except where Council's prior written consent has been obtained. The felling, lopping, topping, ringbarking, wilful destruction or removal of any tree/s unless in conformity with this approval or subsequent approval is prohibited.

All healthy trees and shrubs identified for retention on the approved drawings are to be suitably protected in accordance with Section 4, Tree protection measures, and Appendix C Tree Protection Zone Sign, of Australian Standard AS4970 - 2009, Protection of Trees on Development Sites, prior to the commencement of any works (including any demolition and excavation) and maintained for the duration of the works.

In this regard the street tree and all protected trees on or adjacent to the site will be protected as described below;

- i. A Tree Protection (Management) Plan prepared by a AQF Level 5 Arborist is to be available on site at all times prior to the issue of the Construction Certificate, for all demolition and site works. This Tree Protection (Management) Plan must be shown on the demand of Authorised Council staff.
- ii. Protective perimeter fencing must be consistent with AS 4687, using metal fence posts greater than 20mm diameter and solid or chain wire mesh 2 metres in height supported on concrete pads/feet at 2-2.5 metre spacing. Fencing placement should not be closer than 2.5 metres from the trunk of each protected tree, or at a distance as specified by the approved Tree Protection (Management) Plan and approved by Council's Tree Management Officer. Shade cloth is to be used to prevent entry of dust and contaminated liquids into the root protection area.
- iii. Signs must be placed on the Fencing. These signs must comply with AS1319. The signs must state the purpose of the fencing and the name and contact details of the builder and the appointed AQF Level 5 consultant arborist.
- iv. Root protection is to be provided in the form of mulching to a depth of 50-100mm, inside of the fenced tree protection zone.
- v. Ground (Root) Trunk and Branch Protection must comply with the diagram of Figure 4 of AS4970 – 2009. Ground protection within the tree protection zone and drip line should be in the form of heavy steel plates or timber rumble boards over mulch or aggregate. Trunk and branch protection should be to a minimum height of 2 metres and must include measures to protect the tree/s against damage from the movement of trucks, plant equipment and materials at greater heights above ground level.

- vi. Temporary signs, cables, wires must not be attached to, or suspended, on any street tree or protected tree.
- vii. Above ground utilities must not be placed within the canopy of an existing protected tree, or create the future need for clearance pruning.
- viii. Below ground utilities/services must not be located inside the fenced tree protection zone.
- ix. Scaffolding must not be located in the fenced tree protection zone unless authorised by the approved Tree Protection (Management) Plan and Council's Tree Management Officer
- x. Council must be notified in writing within 24 hours, for all temporary removal of the tree protection fencing ground (root) trunk and branch protection within the root protection area.
- xi. Pruning of a street tree is prohibited without the written consent of Council.

(Reason: To ensure the protection of trees to be retained on the site.)

10. MATERIALS – CONSISTENT WITH SUBMITTED SCHEDULE (GC)

All external materials, finishes and colours are to be consistent with the schedule submitted and approved by Council with the development application.

(Reason: To ensure compliance with this consent.)

11. PRINCIPAL CERTIFYING AUTHORITY (PCA) IDENTIFICATION SIGN (GC)

Prior to commencement of any work, signage must be erected in a prominent position on the work site identifying:

- i) The Principal Certifying Authority (PCA) by showing the name, address and telephone number of the PCA;
- ii) The Principal Contractor by showing the Principal Contractor's name, address and telephone number (outside of work hours) for that person; and
- iii) The sign must state that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the work is being carried out, but must be removed when the work has been completed.

This clause does not apply to building work, subdivision work or demolition work that is carried out inside an existing building that does not affect the external walls of the building.

(Reason: Statutory requirement.)

12. PRIVACY - SCREEN PLANTING TO SIDE AND REAR BOUNDARIES (GC)

Evergreen shrubs with a minimum 5 litre container size achieving a minimum mature height of 3m shall be planted along the side and rear boundaries to provide suitable privacy screening. Screen planting shall be maintained at all times. Details of the selected plants shall be submitted to and approved by the Principal Certifying Authority. Compliance with this condition shall be certified by the Principal Certifying Authority, prior to occupation of the premises.

(Reason: To maintain privacy amenity to neighbouring residences.)

13. SITE MANAGEMENT (DURING DEMOLITION AND CONSTRUCTION WORKS)

All of the following are to be satisfied/complied with during demolition, construction and any

other site works:

- i) All demolition is to be carried out in accordance with Australian Standard AS 2601-2001.
- ii) Demolition must be carried out by a registered demolition contractor.
- iii) A single entrance is permitted to service the site for demolition and construction. Protection pads are to be installed to the kerb, gutter and nature strip where trucks and vehicles enter the site.
- iv) No blasting is to be carried out at any time during construction of the building.
- v) Care must be taken during demolition/ excavation/ building/ construction to prevent any damage to adjoining buildings.
- vi) Adjoining owner property rights and the need for owner's permission must be observed at all times, including the entering onto land for the purpose of undertaking works.
- vii) Any demolition and excess construction materials are to be recycled wherever practicable.
- viii) The disposal of construction and demolition waste must be in accordance with the requirements of the Protection of the Environment Operations Act 1997.
- ix) All waste on the site is to be stored, handled and disposed of in such a manner as to not create air pollution (including odour), offensive noise or pollution of land and/or water as defined by the Protection of the Environment Operations Act 1997. All excavated material should be removed from the site in an approved manner and be disposed of lawfully to a tip or other authorised disposal area.
- x) All waste must be contained entirely within the site.
- xi) A site plan including temporary waste storage locations, construction material storage areas and vehicular access to and from the site must be included with application.
- xii) Section 143 of the Protection of the Environment Operations Act 1997 requires waste to be transported to a place which can lawfully accept it. All non-recyclable demolition materials are to be disposed of at an approved waste disposal depot in accordance with legislation.
- xiii) Details as to the method and location of disposal of demolition materials (weight dockets, receipts, etc.) should be kept on site as evidence of approved methods of disposal or recycling and must be presented to Council and/or Principal Certifying Authority upon request.
- xiv) All materials on site or being delivered to the site are to generally be contained within the site. The requirements of the Protection of the Environment Operations Act 1997 must be complied with when placing/stockpiling loose material, disposing of concrete waste, or other activities likely to pollute drains or water courses.
- xv) Any materials stored on site must be stored out of view or in such a manner so as not to cause unsightliness when viewed from nearby lands or roadways.
- xvi) Public footways, include nature strips and roadways adjacent to the site must be maintained and cleared of obstructions during construction. No building materials, waste containers or skips may be stored on the road reserve or footpath without prior separate approval from Council, including payment of relevant fees.
- xvii) Building operations such as brick-cutting, washing tools or paint brushes, and mixing mortar not be performed on the roadway or public footway or any other locations which could lead to the discharge of materials into the stormwater drainage system.
- xviii) All site waters during excavation and construction must be contained on site in an approved manner to avoid pollutants entering into waterways or Council's stormwater drainage system.
- xix) Any work must not prohibit or divert any natural overland flow of water.
- xx) Toilet facilities for employees must be provided in accordance with WorkCover NSW.

(Reason: To ensure that demolition, building and any other site works are undertaken in

accordance with relevant legislation and policy and in a manner which will be non-disruptive to the local area.)

14. **WASTE – TRACKABLE (GC)**

Removal of trackable waste (as defined by the NSW Environment Protection Authority) from the site must comply with the Protection of the Environment Operations (Waste) Regulation 2005 for the transportation, treatment and disposal of waste materials. Waste materials must not be disposed on land without permission of the land owner and must with the provisions of the Protection of the Environment and Operations Act 1997.

(Reason: To ensure compliance with legislation.)

15. **CLASSIFICATION OF WASTE (GC)**

Prior to the exportation of waste (including fill or soil) from the site, the waste materials must be tested and classified in accordance with the provisions of the protection of the environment operations act 1997 and the NSW EPA waste classification guidelines, part 1: classification of waste (November 2014). Testing is required prior to off-site disposal. In accordance with DECC waste classification guidelines (2014) materials identified for off-site disposal must be removed by a suitably qualified contractor to an appropriately licensed waste facility.

Note: attention is drawn to part 4 of the NSW DECC waste classification guidelines (2014) which makes particular reference to the management and disposal of acid & potential acid sulfate soils. The classification of the material is essential to determine where the waste may be legally taken. The protection of the environment operations act 1997 provides for the commission of an offence for both the waste owner and the transporters if the waste is taken to a place that cannot lawfully be used as a waste facility for the particular class of waste. For the transport and disposal of industrial, hazardous or group a liquid waste advice should be sought from the EPA.

Evidence that the requirements specified above have been satisfied must be provided to the Council and/or Principal Certifying Authority prior to the issue of an occupation certificate. Where an occupation certificate is not required this evidence must be provided to the satisfaction of Council.

(Reason: To ensure compliance with legislation.)

16. **STORMWATER MANAGEMENT PLAN - CERTIFICATION REQUIREMENT (GC)**

A detailed Stormwater Management Plan (SWMP) in line with Council's Stormwater Management Code is to be prepared and certified by an Accredited Civil/Hydraulic Engineer and submitted to the Principal Certifying Authority and Council, prior to the issue of a Construction Certificate. The SWMP is to be based on the approved development as modified by any conditions of consent.

(Reason: To ensure appropriate provision is made for the disposal and management of stormwater generated by the development, and to ensure public infrastructure in Council's care and control is not overloaded.)

17. **SYDNEY WATER - TAP IN™ (GC)**

The approved plans must be submitted to a Sydney Water Tap in™ to determine whether the development application will affect Sydney Water's sewer and water mains, stormwater drains and/or easements, and if further requirements need to be met. The approved plans

will be appropriately endorsed. For details please refer to 'Plumbing, building and developing' section of Sydney Water's web site at www.sydneywater.com.au then see 'Building', or telephone 13000 TAP IN (1300 082 746). The Certifying Authority must ensure that a Tap in™ agent has appropriately stamped the plans prior to the issue of the Construction Certificate.

(Reason: Compliance with Sydney Water requirements.)

18. UTILITIES AND SERVICES - PROTECTION OF (GC)

Any footings or excavation to be located or undertaken adjacent to Council's stormwater must be designed to address the following requirements:

- i) All footings and excavation must be located wholly within the site and clear of any easement boundaries;
- ii) All footings and excavation must be located a minimum of 1000mm from the centreline of the pipeline or 500mm from the outside of the pipeline, whichever is the greater distance from the centreline; and
- iii) Footings must extend to at least the depth of the invert of the pipeline unless the footings are to be placed on competent bedrock.

If permanent excavation is proposed beneath the obvert of the pipeline, suitable means to protect the excavation and proposed retaining structures from seepage or other water flow from the pipeline and surrounding subsoil, must be provided. The design must be prepared by a qualified practicing Structural/Civil Engineer.

Construction plans must be approved by the appropriate utility's office (e.g. council, Sydney Water Corporation) to demonstrate that the development complies with the utility's requirements.

The applicant must provide written evidence (e.g. compliance certificate, formal advice) of compliance with the requirements of all relevant utility providers (e.g. Water, Energy, Telecommunications, Gas).

(Reason: To ensure protection of Council assets.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF A CONSTRUCTION CERTIFICATE (PCC)

19. ACID SULPHATE SOILS (CC)

The construction works must All recommendations made In the Preliminary Site Investigation dated 20 May 2020 prepared by GeoEnviro Consultancy Pty Ltd must be implemented. Any change made to the site that will or is likely to impact the recommendations of the Preliminary Site Investigation will require a further assessment and is to be provided to Council prior to the commencement of works.

(Reason: Statutory compliance and environmental protection.)

20. BASIX COMMITMENTS (CC)

The approved BASIX Certificate shall be submitted to the Principal Certifying Authority with the application for a Construction Certificate.

Where a change or changes are proposed in the BASIX commitments, the applicant must

submit a new BASIX Certificate to the Principal Certifying Authority and Council. If any proposed change in the BASIX commitments is inconsistent with the development consent the applicant will be required to submit a modification to the development consent to Council under Section 4.55 of the Environmental Planning and Assessment Act 1979.

All commitments in the BASIX Certificate must be shown on the plans accompanying the Construction Certificate.

(Reason: Statutory compliance.)

21. BUILDING CODE OF AUSTRALIA - COMPLIANCE WITH (CC)

All architectural drawings, specifications and related documentation shall comply with the Building Code of Australia (BCA). All work must be carried out in accordance with the requirements of the Building Code of Australia (BCA).

In the case of residential building work for which the Home Building Act 1989 requires there to be a contract of insurance in force in accordance with Part 6 of that Act, such a contract of insurance is to be in force before any building work authorised to be carried out by the consent commences.

Details demonstrating compliance with this condition are to be submitted to the Principle Certifying Authority, prior to issue of the Construction Certificate.

(Reason: This is a 'prescribed' condition under clause 98(1) of the Environmental Planning and Assessment Regulation 2000.)

22. CAR PARKING - VEHICULAR ACCESS RAMPS (CC)

Vehicular access ramps shall comply with the provisions of AS/NZS 2890.1:2004 and the Strathfield Consolidated DCP 2005. Plans to be submitted shall contain the following details:

- i) A minimum 1m x 1m splay provided at the vehicular access driveway on both sides of the driveway along the property boundary to maintain sight lines for pedestrians and motorists. The areas should be kept clear from obstructions and only allow for groundcover landscaping, as per the Strathfield Consolidated DCP 2005.
- ii) Certification that the design complies with AS/NZS 2890.1:2004 and the Strathfield Consolidated DCP, by a qualified engineer.
- iii) Longitudinal section along the extreme wheel paths of each driveway/access ramp at a scale of 1:25 demonstrating compliance with the scraping provisions of AS/NZS 2890.1:2004. It shall include all levels and grades, including those levels stipulated as boundary levels, both existing and proposed. It shall extend from the centre-line of the roadway through to the parking area.
- iv) Longitudinal section along the gutter line showing how it is intended to transition the vehicular crossing into the existing kerb and gutter. Boundary levels shall generally run parallel with the kerb levels.
- v) Location of verge trees, street furniture and service installations.
- vi) Superimposition of vehicle turning circles for access into parking spaces.

The certification referred to in (vi) above shall be submitted to the Principal Certifying Authority prior to the issue of a Construction Certificate (for the design) and to the Principal Certifying Authority prior to the issue of any Occupation Certificate for the 'as-built works'.

(Reason: To ensure adequate vehicular access can be achieved.)

23. CAR PARKING - COMPLIANCE WITH AS/NZS 2890.1:2004 (CC)

Car parking dimensions must comply with the Australian/New Zealand Standard AS/NZS 2890.1:2004 - Parking facilities - Off-street car parking. Details demonstrating compliance are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To ensure compliance with Australian Standards relating to parking of vehicles.)

24. CAR PARKING - VEHICULAR CROSSING WIDTH AT PROPERTY BOUNDARY (CC)

Vehicular crossings are to have a maximum width of 3m at the property boundary. Details demonstrating compliance are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

The vehicular crossing (and all associated excavation works) must not be constructed closer than 2 metres from a retained protected street tree.

(Reason: Compliance with SCDPC 2005.)

25. COMMENCEMENT OF WORKS (NO WORKS UNTIL A CC IS OBTAINED)

Building work, demolition or excavation must not be carried out until a Construction Certificate has been issued by either Strathfield Council or a Principal Certifying Authority.

Demolition of any part of a building triggers 'commencement of erection of building' pursuant of section 4.19 of the EP&A Act 1979. Accordingly, demolition works must not commence until a Construction Certificate has been issued, a Principal Certifying Authority has been appointed and a Notice of Commencement has been issued.

(Reason: To ensure compliance with statutory provisions.)

26. COUNCIL PERMITS – FOR ALL ACTIVITIES ON COUNCIL LAND (CC)**Works Permit**

(as per Section 68 of the Local Government Act 1993 and Section 138 and 139 of the Roads Act 1993)

A Works Permit is required for construction of a vehicular crossing (driveway), new stormwater down pipe connection to kerb and gutter, new footpath and/or stormwater connection. A Works Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Standing Plant Permit

This permit must be applied for where it is intended to park a concrete pump, crane or other plant on the roadway or footpath. A Standing Plant Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Skip Bin Permit

This permit must be applied for if you intend to place a skip bin on the roadway or footpath. A Skip Bin Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on

Council's website.

Temporary Full or Part Road Closure Permit

This permit must be applied for if you require a full or a part road closure to take place to assist in your construction works. Please use the Works Permit Application Form, which is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Hoarding/Fencing Permit

This permit must be applied for if you intend to erect a Class A (fence type) or Class B (overhead type) hoarding/fencing along the street frontage(s). A Hoarding Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Work Zone Permit

This permit must be applied for if you require permanent parking along the kerbside at the front of the site during construction works. A Work Zone Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Ground Anchoring Permit

This permit must be applied for, for the installation of ground anchors under Council's footway/road reserve. It does not cover ground anchors under private properties. A separate approval is required to be obtained from Roads and Maritime Services (RMS) if it is proposed to install ground anchors under a State or Classified Regional Road (please refer to the end of this application form for more information).

(Reason: Council requirement.)

27. **EROSION AND SEDIMENTATION CONTROL PLAN (CC)**

An Erosion and Sediment Control Plan is to be prepared where construction or excavation activity requires the disturbance of the soil surface and existing vegetation. Details including drawings and specifications must provide adequate measures for erosion and sediment control to ensure:

- i) Compliance with the approved Soil and Water Management Plan.
- ii) Removal or disturbance of vegetation and top soil is confined to within 3m of the approved building area (no trees to be removed without approval).
- iii) All uncontaminated run-off is diverted around cleared or disturbed areas.
- iv) Silt fences or other devices are installed to prevent sediment and other debris escaping from the cleared or disturbed areas into drainage systems or waterways.
- v) All erosion and sediment controls are fully maintained for the duration of demolition/development works.
- vi) Controls are put into place to prevent tracking of sediment by vehicles onto adjoining roadways.
- vii) All disturbed areas are rendered erosion-resistant by turfing, mulching, paving or similar.
- viii) All water pumped or otherwise removed from excavations or basement areas is filtered to achieve suspended solids/non filterable residue levels complying with the Australian Water Quality guidelines for Fresh and Marine Waters.
- ix) Pumped or overland flows of water are discharged so as not to cause, permit or allow erosion before the commencement of work (and until issue of the occupation certificate).

Details of the proposed soil erosion and sedimentation controls are to be submitted to the Principal Certifying Authority with the Construction Certificate Application. Under no circumstances are any works to commence, prior to these details being approved by the Principal Certifying Authority and the controls being in place on the site.

(Reason: Environmental protection.)

28. **LANDSCAPING - MAINTENANCE STRATEGY (CC)**

To ensure the survival of landscaping following works, a landscape maintenance strategy for the owner/occupier to administer over a 12 month establishment period following the issue of the Occupation Certificate shall be prepared and provided to the satisfaction of the Principal Certifying Authority with the Construction Certificate application. The strategy is to address maintenance issues such as, but not limited to plant survival, irrigation, soil testing, weeding, staking, fertilizing, remedial pruning and plant replacement.

(Reason: Ensure landscape survival.)

29. **NOISE – CONSTRUCTION CC)**

All works carried out on site during construction/demolition/excavation/earthworks shall comply with the NSW Protection of the Environment Operations Act 1997, the Department of Environment and Climate Changes “Interim construction noise guideline” and AS 2436-2010 – “Guide to noise and vibration control on construction, demolition and maintenance sites” for the control of construction noise which specifies that:

- Construction period of 4 weeks and under – The L90 Level measured over a period of not less than 15 minutes when the construction site is operating must not exceed the background level by more than 20 dB(A) at the boundary.
- Construction period greater than 4 weeks but not exceeding 26 weeks – The L90 level measured over a period of not less than 15 minutes when the construction site is operating must not exceed the background level by more than 10 dB(A) at the boundary.
- Construction period exceeding 26 weeks – The L90 level measured over a period of not less than 15 minutes when the construction site is operating must not exceed the background level by more than 5 dB(A) at the boundary.

Should complaints of a noise nuisance be substantiated, Council may require the acoustic treatment of the premises to ensure compliance with the NSW Department of Environment and Climate Changes “Interim construction noise guideline” and AS 2436-2010 – “Guide to noise and vibration control, demolition and maintenance sites” for the control of construction noise. A further acoustic assessment and report will be required to be provided to Council assessing the premises in working order.

(Reason: Noise attenuation.)

30. **PRIVACY - OBSCURE GLAZING IN WET AREAS (CC)**

All bathroom, ensuite and toilet windows shall be installed with obscure glazing. Plans shall be notated accordingly and details demonstrating compliance submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Privacy amenity.)

31. **SECTION 7.12 CONTRIBUTION PAYMENT - INDIRECT CONTRIBUTIONS PLAN) (CC)**

In accordance with the provisions of Section 7.13 of the Environmental Planning and Assessment Act 1979 and the Strathfield Indirect Development Contributions Plan 2010-2030, a contribution in the form of cash, cheque or credit card (financial transaction fee applies) shall be paid to Council for the following purposes:

Local Amenity Improvement Levy **\$14,190.00**

The total amount of the contribution is valid as at the date of determination and is subject to quarterly indexation. The amount of the contribution under this condition shall be indexed in accordance with clause 4.12 of the Strathfield Indirect Development Contributions Plan 2010-2030.

Contributions must be receipted by Council and submitted to the Accredited Certifier, prior to the issue of any Construction Certificate.

A copy of this condition is to be presented to Council's Customer Service Centre when paying the contribution so that it can be recalculated.

Note: A copy of Strathfield Council's Section 7.12 Indirect Development Contributions Plan may be downloaded from Council's website.

(Reason: To enable the provision of public amenities and services required/anticipated as a consequence of increased demand resulting from the development.)

32. **STORMWATER - RAINWATER RE-USE (CC)**

A rainwater re-use system shall be provided in accordance with either the BASIX minimum requirements, any relevant Council Rainwater Policy and/or specification of the management of stormwater, whichever is applicable. A detailed stormwater plan showing the proposed re-use system shall be submitted to and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Compliance and amenity.)

33. **STORMWATER DRAINAGE (CC)**

The following stormwater precautions are required to be provided on the site:

- i) Grated drains shall be provided along the driveway/basement entry at the vehicular crossing(s) and are to connect to the internal drainage system.
- ii) Overflow paths shall be provided to allow for flows in excess of the capacity of the pipe/drainage system draining the site.
- iii) Allowance shall be made for surface runoff from adjacent properties, and to retain existing surface flow path systems through the site. Any redirection or treatment of these flows shall not adversely affect any other properties
- iv) Boundary fencing shall be erected in such a manner as not to interfere with the natural flow of ground and surface water to the detriment of any other party.

(Reason: To ensure the site is drained appropriately and does not interfere with the natural flow of flood waters.)

34. **SWIMMING POOLS / SPAS (CONSTRUCTION OF)**

The approved swimming pool/spa must comply with all relevant legislation including:

- i) Swimming Pools Amendment Act 1992 (as amended);
- ii) Swimming Pools Regulations 2008; and
- iii) Australian Standard AS1926.1-2012 – Safety Barriers for Swimming Pools.

Details demonstrating compliance with this condition shall be demonstrated to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Safety and statutory compliance.)

35. **SWIMMING POOLS / SPAS - MECHANICAL PLANT ENCLOSURE (CC)**

Any mechanical plant associated with the swimming pool and spa shall be acoustically treated to comply with the Protection of the Environment Operations Act 1997. Details are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To ensure the acoustic amenity of the neighbouring residents.)

36. **SECURITY PAYMENT – DAMAGE DEPOSIT FOR COUNCIL INFRASTRUCTURE (CC)**

A security (damage deposit) A security (damage deposit) of **\$15,200.00** (calculated in accordance with Council's adopted Fees and Charges) shall be paid to Council, prior to the issue of a Construction Certificate.

The deposit is required as security against any damage to Council property during works on the site. The applicant must bear the cost of all restoration works to Council's property damaged during the course of this development. All building work must be carried out in accordance with the Building Code of Australia.

Payment may be accepted in the form of cash, bank guarantee, cheque or credit card (financial transactions fees apply). Note: Additional fees apply for the lodgement of a bank guarantee in lieu of cash bond applies in accordance with Council's adopted Fees and Charges.

Any costs associated with works necessary to be carried out to rectify any damages caused by the development, shall be deducted from the Damage Deposit.

Note: Should Council property adjoining the site be defective e.g. cracked footpath, broken kerb etc., this should be reported in writing, or by photographic record, submitted to Council at least seven (7) days prior to the commencement of any work on site. This documentation will be used to resolve any dispute over damage to infrastructure. It is in the applicant's interest for it to be as full and detailed as possible.

The damage deposit shall be refunded upon completion of all works upon receipt of a Final Occupation Certificate stage and inspection by Council.

(Reason: Protection of Council infrastructure.)

37. **TREE BONDS (CC)**

A tree bond of **\$3,000.00** (calculated in accordance with Council's adopted Fees and Charges) shall be paid to Council, prior to the issue of a Construction Certificate.

The deposit is required as security against any damage to existing trees to be retained on Council's road reserve, during works on the site. The applicant must bear the cost of all restoration works to Council's property damaged during the course of this development.

Payment may be accepted in the form of cash, bank guarantee, cheque or credit card (financial transactions fees apply). Note: Additional fees apply for the lodgement of a bank guarantee in lieu of cash bond applies in accordance with Council's adopted Fees and Charges.

A refund of the Tree Bond must be made in writing.

Tree Bonds may be forfeited if a tree is dead, made dangerous or has been terminally damaged, or will be held until tree/s have fully recovered from the construction damage or were replacement/planted trees have become fully established and are over 6 metres in height.

(Reason: To ensure the protection of trees to be retained on Council's Road Reserve.)

38. UTILITIES AND TELECOMMUNICATIONS - ELECTRICITY CONNECTION (CC)

Provision must be made for connection to future underground distributions mains. This must be achieved by installing:

- i) An underground service line to a suitable existing street pole; or
- ii) Sheathed underground consumers mains to a customer pole erected near the front property boundary (within 1 metre).

Note: A limit of one (1) pole per site will apply.

Any costs associated with the relocation of the above are at the requestor's expense. Any disturbance to public land as a result of the undergrounding of services shall be restored at no cost to Council.

Details are to be submitted to the Principal Certifying Authority with the Construction Certificate Application.

(Reason: Environmental amenity.)

39. UTILITIES AND TELECOMMUNICATIONS - TELECOMMUNICATIONS ASSETS (CC)

Provision must be made for relocation of telecommunications network assets including underground placement of any existing aerial cables and infrastructure. Any costs associated with the relocation of the above are at the requestor's expense. Any disturbance to public land as a result of the undergrounding of services shall be restored at no cost to Council.

Details are to be submitted to the Principal Certifying Authority with the Construction Certificate application.

(Reason: To ensure suitable relocation of telecommunications infrastructure if required.)

40. VEHICULAR CROSSINGS - WORKS PERMIT FOR CONSTRUCTION OF (CC)

Full-width, heavy-duty concrete vehicular crossing(s) shall be provided across the footpath at the entrance(s) and/or exit(s) to the site and designed in accordance with Council's guidelines and specifications. In this regard, a Works Permit is to be obtained (available from Council's Customer Services Centre or downloaded from Council's website), and the appropriate fees and charges paid, prior to the lodgement of a Construction Certificate.

(Reason: To ensure appropriate access to the site can be achieved.)

41. WATER SUSTAINABILITY – GENERALLY (CC)

Water collected in the rainwater tank must comprise roof water only and not surface water. Water from the rainwater tank must only be used for following purposes and not for human consumption:

- i) Toilet flushing;
- ii) Clothes washing;
- iii) Garden irrigation;
- iv) Car washing and similar outdoor uses;
- v) Filling swimming pools, spa pools and ornamental ponds; and
- vi) Fire fighting.

(Reason: To promote sustainable water management practice.)

42. WATER HEATING SYSTEMS - LOCATION OF (CC)

Water heating systems shall be located so as not to be visible from public places and the ground level of adjoining properties. Details (type and location) of the water heaters shall be submitted to and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To maintain streetscape character.)

CONDITIONS TO BE SATISFIED PRIOR TO THE COMMENCEMENT OF WORKS (PCW)

43. APPOINTMENT OF A PRINCIPAL CERTIFYING AUTHORITY (PCA) (CW)

No work shall commence in connection with this Development Consent until:

- i) A construction certificate for the building work has been issued by the consent authority or a Principal Certifying Authority.
- ii) The person having the benefit of the development consent has appointed a principal certifying authority for the building work, and notified the principal certifying authority that the person will carry out the building work as an owner/builder, if that is the case.
- iii) The principal certifying authority has, no later than 2 days before the building work commences:
 - notified the Council of his or her appointment, and
 - notified the person having the benefit of the development consent of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- iv) The person having the benefit of the development consent, if not carrying out the work as an owner-builder, has:
 - appointed a principal contractor for the building work who must be the holder of a contractor licence if any residential building work is involved;
 - notified the principal certifying authority of such appointment; and
 - unless that person is the principal contractor, notified the principal contractor of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- v) The person having the benefit of the development consent has given at least 2 days' notice to the Council of the person's intention to commence the erection of the building.

Note: If the principal certifying authority is the Council, the nomination will be subject to the payment of a fee for the service to cover the cost of undertaking all necessary inspections and the issue of the appropriate certificates.

Under the Environment Planning and Assessment (Quality of Construction) Act, 2003, a sign must be erected in a prominent position on the work site showing the name, address and telephone number of the principal certifying authority; the name of the principal contractor (if any) for the building work and a telephone number at which that person may be contacted outside working hours. That sign must also state that unauthorised entry is prohibited. The sign must not be removed until all work has been completed.

(Reason: Statutory requirement.)

44. **HOME BUILDING COMPENSATION FUND (CW)**

No residential building work within the meaning of the Home Building Act 1989 may commence until:

- i) A contract of insurance in accordance with Part 6 of the Home Building Act 1989 is entered into and in force, where such a contract is required under that Act (this is a prescribed condition of consent pursuant to clause 981(b) Environmental Planning and Assessment Regulation 2000.
- ii) The PCA is satisfied that the principal contractor for the work is the holder of the appropriate licence and is covered by the appropriate insurance, in each case if required by the Home Building Act 1989 (unless the work is to be carried out by an owner-builder).
- iii) If the work is to be carried out by an owner builder, that the owner builder is the holder of any owner -builder permit required under the Home Building Act 1989.
- iv) Written notice of the following information has been provided to Council (this is a prescribed condition of consent pursuant to clause 98B of the Environmental Planning and Assessment Regulation 2000):
 - In the case of work for which a principal contractor is required to be appointed:
 - the name and licence number of the principal contractor; and
 - the name of the insurer by which the work is insured under Part 6 of the Home Building Act 1989.In the case of work to be done by an owner-builder:
 - the name of the owner-builder; and
 - if the owner-builder is required to hold an owner-builder permit under the Home Building Act 1989, the number of the owner-builder permits.

Where Council is not the PCA, the PCA is responsible for notifying Council of the above matters.

Note: Where arrangements for doing residential building work change while the work is in progress so that the above information becomes out of date, the PCA (where not the Council) must provide Council with written notice of the updated information.

(Reason: Statutory requirement.)

45. **NOTICE OF COMMENCEMENT (CW)**

No work shall commence until the following details are submitted to Council:

- i) A Notice of Commencement (form will be attached with issue of a Construction Certificate or available from our website) within two (2) days of the date on which it is proposed to commence works associated with the Development Consent;

- ii) Details of the appointment of a Principal Certifying Authority (either Council or another Principal Certifying Authority); and
- iii) Details of the name, address and licence details of the Builder.

(Reason: Statutory requirement.)

CONDITIONS TO BE SATISFIED DURING DEMOLITION AND BUILDING WORKS (DBW)

46. ACID SULFATE SOILS MANAGEMENT (DW)

All construction works must be monitored for the presence of acid sulfate soils (ASS) and the following measures must be undertaken during construction:

- During excavation, the subsurface soils should be noted for presence of ASS, which usually occurs as black organic clay and soft peat with sulphuric odour;
- Suspect ASS should be noted for signs of reaction (e.g. oxidation). Common reaction includes pungent odour being released into the air, discolouration of soil (e.g. blue and green tinge) and leaching of iron from the soil; and
- Sampling of soil and laboratory analysis should be carried out to confirm the material is ASS (if required).

In the event where ASS are identified, the soil should be properly managed as follows:

- The excavation must be backfilled and capped as soon as practicable;
- The stockpiles must be placed in a designated area. This area must be lined and appropriate silt fences must be erected to prevent migration of fines.
- This stockpile must be either treated on-site using 10% by weight of lime or removed off-site to an appropriate waste management facility for treatment and disposal.
- All material to be removed from the site must be carried out by a licensed contractor. This material must be sealed and contained on the truck during haulage using appropriate lining and capping material.
- All stockpile material on-site, which could not be immediately attended to must be covered and capped to retard oxidation process.

47. FILL MATERIAL (DW)

The only waste derived material which may be received at the development site is:

- i) Virgin excavated material (within the meaning of the Protection of the Environment Operations Act 1997), and
- ii) any other waste-derived material the subject of a resource recovery exemption under cl.51A of the Protection of the Environment Operations (Waste) Regulation 2005 that is permitted to be used as fill material.

Any (b)-type material received at the development site must be accompanied by documentation certifying by an appropriately qualified environmental consultant the materials compliance with the exemption conditions; and this documentation must be provided to the Principal Certifying Authority on request.

(Reason: To ensure imported fill is of an acceptable standard for environmental protection purposes.)

48. OBSTRUCTION OF PUBLIC WAY NOT PERMITTED DURING WORKS (DW)

The public way must not be obstructed by any materials, vehicles, refuse, skips or the like, under any circumstances, without the prior approval of Council.

(Reason: To maintain public access and safety.)

49. PUBLIC INFRASTRUCTURE AND SERVICES (DW)

The applicant must comply with the requirements (including financial costs) of any relevant utility provider (e.g. Energy Australia, Sydney Water, Telstra, RMS, Council etc.) in relation to any connections, works, repairs, relocation, replacements and/or adjustments to public infrastructure or services affected by the development.

(Reason: To maintain public infrastructure and/or services.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF AN OCCUPATION CERTIFICATE (POC)

50. DRAINAGE SYSTEM - MAINTENANCE OF EXISTING SYSTEM (OC)

Where elements of the existing drainage system are to be utilised, the existing drainage system shall be overhauled and maintained clear of silt and accumulated debris. Silt and the like shall be removed, not flushed from the system.

A certificate shall be provided by a suitably qualified person (a registered plumber or a person of equivalent or greater experience or qualification) to the satisfaction of the Principal Certifying Authority, prior to the issue of any Occupation Certificate to confirm that the system is in good working order and adequate to accept additional flows having regard to any relevant standards and/or Sydney Water requirements.

(Reason: Maintenance and environment.)

51. ENGINEERING WORKS (CERTIFICATION OF)

Prior to occupation of the premises, a Work As Executed (WAE) Plan of all engineering and/or drainage works is to be submitted to the Principal Certifying Authority. The WAE Plan is to be certified by an Accredited Civil/Hydraulic Engineer demonstrating that:

- i) The stormwater drainage system; and/or
- ii) The car parking arrangement and area; and/or
- iii) Any related footpath crossing works; and/or
- iv) The proposed basement pump and well system; and/or
- v) The proposed driveway and layback; and/or
- vi) Any other civil works

have been constructed in accordance with the approved plans and any relevant Standards and Council policies/specifications.

For major works, such as subdivisions, works within the road reserve (requiring separate S138 approval) and as where specified by Council, a Part 4A Certificate will be required. It is strongly recommended that an Engineer supervise all engineering related works.

Where Council is not the Principal Certifying Authority, an electronic copy of the above documents is to be provided to Council, prior to the issue of any Occupation Certificate.

(Reason: Asset management.)

52. OCCUPATION OF BUILDING (OC)

A person must not commence occupation or use (or change of use where an existing

building) of the whole or any part of a new building (within the meaning of section 109H (4) of the Act) unless an Interim Occupation Certificate or Final Occupation Certificate has been issued in relation to the building or part.

The Principal Certifying Authority is required to be satisfied, amongst other things, that:

- i) All required inspections (including each applicable mandatory critical stage inspection) have been carried out; and
- ii) Any preconditions to the issue of the certificate required by a development consent have been met.

Note: New building includes an altered portion of, or an extension to, an existing building.

(Reason: Statutory requirement.)

53. RAINWATER TANKS (OC)

Rainwater tanks must be installed on residential properties by a suitably qualified and licensed plumber and in accordance with the following:

- i) Australian/New Zealand Standard AS/NZS 3500:2003;
- ii) NSW Code of Practice Plumbing and Drainage, 2006 produced by Committee on Uniformity of Plumbing and Drainage Regulations in NSW (CUPDR); and
- iii) Council's rainwater tank policy.

Details demonstrating compliance with this condition are to be submitted to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To protect public health and amenity.)

54. STORMWATER - CERTIFICATION OF THE CONSTRUCTED DRAINAGE SYSTEM (OC)

The constructed stormwater system shall be certified by a suitably qualified person, in accordance with Council's Stormwater Management Code, prior to the issue of any Occupation Certificate.

(Reason: Adequate stormwater management.)

55. SWIMMING POOLS / SPAS - REGISTRATION AND REQUIREMENTS (OC)

The approved swimming pool/spa must comply with all relevant legislation including:

- i) Swimming Pools Amendment Act 1992 (as amended);
- ii) Swimming Pools Regulations 2008; and
- iii) Australian Standard AS1926.1-2012 – Safety Barriers for Swimming Pools.

Swimming pool owners must register their swimming pool or spa on the NSW Swimming Pool Register. A copy of a valid certificate of compliance or relevant occupation certificate must be attached to new residential tenancy agreements to rent property with a swimming pool or spa pool. Note: This requirement does not apply to a lot in strata or community title schemes with more than two lots.

A copy of a valid certificate of compliance or relevant occupation certificate must be attached to new residential tenancy agreements to rent property with a swimming pool or spa pool. Note: This requirement does not apply to a lot in strata or community title schemes with more than two lots; or for any off the plan contacts.

Details demonstrating compliance with this condition shall be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: Safety and statutory compliance.)

RESOLUTION

The application be **APPROVED** subject to the recommended conditions and amendments to Conditions 8 and 19 and the deletion of Condition 22 as follows:

8. **LANDSCAPING - CANOPY TREES IN FRONT SETBACK AND REAR YARD (GC)**

New development shall provide a total of three (3) canopy trees, one (1) tree within the front setback adjacent the front boundary and two (2) within the rear yard of the new dwelling. New canopy trees shall be at least three (3) metres high at the time of planting and capable of reaching a mature height of 10m.

Species shall be selected from Council's Recommended Tree List (Available from Council's website or from the Customer Service Centre). Compliance with this condition is to be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To ensure the landscape character of the locality is maintained.)

19. **ACID SULPHATE SOILS (CC)**

All recommendations made in the Preliminary Site Investigation dated 20 May 2020 prepared by GeoEnviro Consultancy Pty Ltd must be implemented. Any change made to the site that will or are likely to impact the recommendations of the Preliminary Site Investigation will require further assessment and are to be submitted to Council prior to the commencement of works.

(Reason: Statutory compliance and environmental protection.)

FOR: S. Clements, K. Lindeberg, G. Andonoski

AGAINST: Nil

**** End Minutes - Report No. 2****

TO: Strathfield Internal Development Assessment Panel Meeting - 5 June 2020
REPORT: IDAP – Report No. 3
SUBJECT: 2018/115/2 - 31 BODEN AVENUE, STRATHFIELD - LOT 60 DP 15955
DA NO. 2018/115/2

RECOMMENDATION

Pursuant to Section 4.55(2) of the Environmental Planning and Assessment Act 1979, the proposed modification(s) to Development Consent No. DA2018/115/2 involving the minor redesign of front façade at 31 Boden Avenue, Strathfield be **APPROVED**, subject to:

1. The original conditions of consent of Development Application No. (DA2018/115) as approved by IDAP on 22 November 2018 for the demolition of existing structures and construction of a new two storey residential dwelling with a basement and a swimming pool.
2. As modified by the Section 4.55(2) application (DA2018/115/2) as follows:
 - Add Special Condition 1 – Use of the Development
 - Modify Special Condition 2 – Use of the Storage Room within the Basement
 - Add Special Condition 7 – First Floor Balconies and Surrounding Areas
 - Add Special Condition 8 – First Floor Void Space
 - Modify General Condition 8 – Approved Plans and Reference Documentation
 - Modify General Condition 13 – Landscape Adjacent Swimming Pools/Spas
 - Modify Construction Certificate Condition 19 – BASIX Commitments
 - Add Construction Certificate Condition 20 – Privacy Screen
 - Add Construction Certificate Condition 21 – Windows to be Opaque

Accordingly, Development Consent No. DA2018/115/2 is approved as following:

SPECIAL CONDITIONS (SC)

1. USE OF THE DEVELOPMENT (SC)

The proposed development shall not be used as any other use other than a dwelling house, or a use that is specified as exempt development under an applicable Environmental Planning Instrument, subject to its standards.

(Reason: To ensure satisfaction of the provisions under S4.15(1) of the Environmental Planning and Assessment Act 1979)

MODIFIED: 29 May 2020 (DA2018/115/2)

2. USE OF THE STORAGE ROOM WITHIN THE BASEMENT (SC)

The Workshop and Storage and Service Rooms ~~room~~ within the basement is not to be used for habitable purposes at any time.

(Reason: To ensure compliance with Clause 4.4C of the SLEP 2012.)

MODIFIED: 29 May 2020 (DA2018/115/2)

3. GEOTECHNICAL REPORT (SC)

Excavation of the site is to extend only to that area required for building works depicted

upon the approved plans. All excess excavated material shall be removed from the site.

No rock breaking or other machinery for the excavation, drilling, cutting or removal of rock shall be used on the site prior to the acceptance by the principal certifying authority of the following documentation:

- (i) A report by a geotechnical engineer detailing the measures recommended in undertaking the works so as to prevent damage to any adjoining or nearby buildings.
- (ii) The type and size of machinery proposed.
- (iii) The routes of all trucks to convey material to and from the site.

(Reason: To minimise any adverse impact of developments and protect the environment.)

4. FENCING - FRONT FENCE HEIGHT (SC)

Solid fencing forward of the building line shall not exceed a height of 1.5m above natural ground level. Plans demonstrating compliance with this condition are to be submitted to Council for approval.

(Reason: To ensure a positive contribution to the streetscape in accordance with the Strathfield Consolidated DCP 2005.)

5. FEES - ADDITIONAL DEVELOPMENT APPLICATION FEES (CC)

In accordance with Regulation 50(1)(c) and the table to Regulation 246 of the Environmental Planning and Assessment Act Council must charge a development application fee based on the estimated cost of works applied for. An assessment of the proposed development against Rawlinson's Australian Construction Handbook 2009 has revealed that the estimated cost of \$1,000,000 is inaccurate.

Council's assessment has provided the following revised estimates:

Construction of the new dwelling with basement,	<u>\$1,463,675.27</u>
TOTAL	\$1,463,675.27

On this basis, the applicable Development Application fee is \$4,308.16 including a \$931.75 Plan First fee.

Noting you have paid DA fees of \$3405.00 to Council, an **outstanding fee of \$903.16** is required and must be paid prior to the issue of any Construction Certificate.

(Reason: Statutory requirement.)

6. NON-TRAFFICABLE ROOF (SC)

The roof of the dwelling and alfresco shall be non-trafficable.

(Reason: To ensure the roof remains non-trafficable.)

7. FIRST FLOOR BALCONIES AND SURROUNDING AREAS (SC)

The first floor balconies, both on the first floor must not be extended and the balustrades shall be constructed in accordance with the balcony dimensions as approved in the plans listed under condition #7 of this Notice of Determination. The area surrounding the rear balcony, outside the master bedroom, and the wrap-around planter box surrounding bedroom 3 and the attached balcony, must not be trafficable.

(Reason: To ensure the roof remains non-trafficable and address visual privacy.)

MODIFIED: 29 May 2020 (DA2018/115/2)

8. FIRST FLOOR VOID SPACE (SC)

The ceiling over the void space on the first floor, must have a ceiling height of no less than 2.1m from the predominant floor level of the first floor or no less than RL 25.8.

(Reason: To ensure any conversion of the void space will not result to a room capable of being habitable. Thus, ensuring satisfaction of S4.15(1) of the EP&A Act 1979 (as amended).

MODIFIED: 29 May 2020 (DA2018/115/2)

GENERAL CONDITIONS (GC)

9. APPROVED PLANS AND REFERENCE DOCUMENTATION (GC)

The development, except where modified by a condition(s) of consent, is to be carried out in accordance with the following plans and reference documentation:

Plans affixed with Council's 'Development Consent' stamp relating to Development Consent No. DA2018/115:

Drawing No.	Title/Description	Prepared by	Issue / Revision & Date	Date received by Council
DA.01 DELETED: 29 May 2020 (DA2018/115/2)	Demolition plan	Bechara Chan and Associates Pty Ltd	Issue A, 29/06/2018	15/08/2018
DA.02	Ground floor plan and level 1 floor plan	Bechara Chan and Associates Pty Ltd	Issue B, 19/09/2018 April 2020	28/09/2018 19/05/2020
Sheet 01 MODIFIED: 29 May 2020 (DA2018/115/2)	Ground Floor Plan / Basement Plan / Calculation Sheet	Vision Group Architects		
DA.03	Roof and site plan and basement plan	Bechara Chan and Associates Pty Ltd	Issue B, 19/09/2018 April 2020	28/09/2018 19/05/2020
Sheet 02 MODIFIED: 29 May 2020 (DA2018/115/2)	First Floor Plan / Roof Site Plan	Vision Group Architects		
DA.04	Elevations /	Bechara Chan	Issue B,	28/09/2018

MINUTES

Sheet 03 MODIFIED: 29 May 2020 (DA2018/115/2)	Sections / Finishes Schedule	and Associates Pty Ltd Vision Group Architects	19/09/2018 April 2020	19/05/2020
DA.05 Sheet 04 MODIFIED: 29 May 2020 (DA2018/115/2)	Front Fence and Sections / Driveway Profile / BASIX Commitments	Bechara Chan and Associates Pty Ltd Vision Group Architects	Issue B, 19/09/2018 April 2020	28/09/2018 19/05/2020
L-01-G Sheet 05 MODIFIED: 29 May 2020 (DA2018/115/2)	Site land and Calculations First Floor – FSR Map / Ground Floor – FSR Map / Basement Level – FSR Map / Ground Floor – Landscape Map Drawing Title: Elevations / Sections / Finishes Schedule	Site Design Studios Vision Group Architects	Issue C B, 14/09/2018 April 2020	28/09/2018 19/05/2020
L-02-G Sheet 07 MODIFIED: 29 May 2020 (DA2018/115/2)	Detailed plan Proposed Shadow Diagram – 22 nd June (Mid Winter)	Site Design Studios Vision Group Architects	Issue C B, 14/09/2018 April 2020	28/09/2018 19/05/2020
L-03-G LP 01 Sheet 1 of 4 MODIFIED: 29 May 2020 (DA2018/115/2)	Detailed plan Landscape Plan	Site Design Studios Dapple Designs	Issue C A, 14/09/2018 15/05/2020	28/09/2018 19/05/2020
L-04-G	Planting	Site Design	Issue C A,	28/09/2018

LP 01 Sheet 2 of 4 MODIFIED: 29 May 2020 (DA2018/115/2)	details Plant List / Specification	Studios Dapple Designs	14/09/2018 15/05/2020	19/05/2020
L-05-C LP 01 Sheet 3 of 4 MODIFIED: 29 May 2020 (DA2018/115/2)	Existing trees Construction Details	Site Design Studios Dapple Designs	Issue C A, 14/09/2018 15/05/2020	28/09/2018 19/05/2020
L-06-C LP 01 Sheet 4 of 4 MODIFIED: 29 May 2020 (DA2018/115/2)	Notes Front Elevation	Site Design Studios Dapple Designs	Issue C A, 14/09/2018 15/05/2020	28/09/2018 19/05/2020
L-01-C DELETED: 29 May 2020 (DA2018/115/2)	Specifications	Site Design Studios	Issue C, 14/09/2018	28/09/2018
H495-S1/3 DELETED: 29 May 2020 (DA2018/115/2)	Stormwater drainage and sediment controls details	TAA Consulting Engineers	Issue A, 25 July 2018	15 August 2018
H495-S2/3 DELETED: 29 May 2020 (DA2018/115/2)	Stormwater drainage and sediment controls details	TAA Consulting Engineers	Issue A, 25 July 2018	15 August 2018
H495-S3/3 DELETED: 29 May 2020 (DA2018/115/2)	Stormwater drainage and sediment controls details	TAA Consulting Engineers	Issue A, 25 July 2018	15 August 2018

Reference Documentation affixed with Council’s ‘Development Consent’ stamp relating to Development Consent No. DA2018/115:

Title / Description	Prepared by	Issue/Revision Date	&	Date received by Council
---------------------	-------------	---------------------	---	--------------------------

Flood Impact Statement	TAA Consulting Engineers	25 July 2018	15 August 2018
Basix Certificate No. 944937S 1077761S	Eco Certificates Pty Ltd Greenworld Architectural Drafting	8 August 2018 24 February 2020	15 August 2018 26 February 2020
Schedule of Colours and Finishes	Bechara Chan and Associates Pty Ltd	-	15 August 2018
DELETED: 29 May 2020 (DA2018/115/2)			

In the event of any inconsistency, the conditions of this consent shall prevail.

(Reason: To ensure that the form of the development undertaken is in accordance with the determination of Council.)

MODIFIED: 29 May 2020 (DA2018/115/2)

10. CONSTRUCTION HOURS (GC)

No construction or any other work related activities shall be carried out on the site outside the hours of 7.00 am to 5.00 pm Mondays to Fridays and 8am to 1pm Saturdays.

No building activities are to be carried out at any time on a Sunday or public holiday.

Where the development involves the use of jackhammers/rock breakers and the like or other heavy machinery, such equipment may only be used between the hours of 7.00 am - 5.00 pm Monday to Friday only.

(Reason: To maintain amenity to adjoining land owners.)

11. CONSTRUCTION WITHIN BOUNDARIES (GC)

The development including but not limited to footings, walls, roof barges and guttering must be constructed wholly within the boundary of the premises. No portion of the proposed structure shall encroach onto the adjoining properties. Gates must be installed so they do not open onto any footpath or adjoining land.

(Reason: Approved works are to be contained wholly within the subject site.)

12. DEMOLITION – GENERALLY (GC)

Alteration and demolition of the existing building is limited to that documented on the approved plans (by way of notation). No approval is given or implied for removal and/or rebuilding of any portion of the existing building which is not shown to be altered or demolished.

(Reason: To ensure compliance with the approved development.)

13. DEMOLITION - SITE SAFETY FENCING (GC)

Site fencing is to be erected to a minimum height of 1.8m complying with WorkCover Guidelines, to exclude public access to the site, prior to any demolition works occurring and maintained for the duration of the demolition works.

If applicable, a separate Hoarding Application for the erection of an A class (fence type) or B class (overhead type) hoarding/fencing along the street frontage(s) complying with WorkCover requirements must be obtained including:

- payment to Council of a footpath occupancy fee based on the area of footpath to be occupied and Council's Schedule of Fees and Charges before the commencement of work; and
- provision of a Public Risk Insurance Policy with a minimum cover of \$10 million in relation to the occupation of and works within Council's road reserve, for the full duration of the proposed works, must be obtained with a copy provided to Council.

(Reasons: Statutory requirement and health and safety.)

14. LANDSCAPING ADJACENT SWIMMING POOLS/SPAS (GC)

A minimum one (1) metre wide landscape strip is to be provided between the swimming pool and adjacent common boundaries. The landscape strip is to be planted with a continuous row of ~~evergreen shrubs~~ of a screening plants with a minimum five (5) litre container size and capable of achieving a minimum mature height of three (3) metres. Details of the selected plants shall be submitted to and approved by the Principal Certifying Authority. Compliance with this condition shall be certified by the Principal Certifying Authority, prior to occupation of the premises.

(Reason: Privacy amenity of adjoining properties.)

MODIFIED: 29 May 2020 (DA2018/115/2)

15. LANDSCAPING - CANOPY TREES IN FRONT SETBACK (GC)

New development shall provide at least two (2) canopy trees within the front setback adjacent the front boundary (existing trees may be included). New canopy trees shall be at least three (3) metres high at the time of planting and capable of reaching a mature height of 10m.

Species shall be selected from Council's Recommended Tree List (Available from Council's website or from the Customer Service Centre). Compliance with this condition is to be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To ensure the landscape character of the locality is maintained.)

16. MATERIALS – CONSISTENT WITH SUBMITTED SCHEDULE (GC)

All external materials, finishes and colours are to be consistent with the schedule submitted and approved by Council with the development application.

(Reason: To ensure compliance with this consent.)

17. SITE MANAGEMENT (DURING DEMOLITION AND CONSTRUCTION WORKS)

All of the following are to be satisfied/complied with during demolition, construction and any other site works:

- i) All demolition is to be carried out in accordance with Australian Standard AS 2601-2001.
- ii) Demolition must be carried out by a registered demolition contractor.

- iii) A single entrance is permitted to service the site for demolition and construction. Protection pads are to be installed to the kerb, gutter and nature strip where trucks and vehicles enter the site.
- iv) No blasting is to be carried out at any time during construction of the building.
- v) Care must be taken during demolition/ excavation/ building/ construction to prevent any damage to adjoining buildings.
- vi) Adjoining owner property rights and the need for owner's permission must be observed at all times, including the entering onto land for the purpose of undertaking works.
- vii) Any demolition and excess construction materials are to be recycled wherever practicable.
- viii) The disposal of construction and demolition waste must be in accordance with the requirements of the Protection of the Environment Operations Act 1997.
- ix) All waste on the site is to be stored, handled and disposed of in such a manner as to not create air pollution (including odour), offensive noise or pollution of land and/or water as defined by the Protection of the Environment Operations Act 1997. All excavated material should be removed from the site in an approved manner and be disposed of lawfully to a tip or other authorised disposal area.
- x) All waste must be contained entirely within the site.
- xi) A site plan including temporary waste storage locations, construction material storage areas and vehicular access to and from the site must be included with application.
- xii) Section 143 of the Protection of the Environment Operations Act 1997 requires waste to be transported to a place which can lawfully accept it. All non-recyclable demolition materials are to be disposed of at an approved waste disposal depot in accordance with legislation.
- xiii) Details as to the method and location of disposal of demolition materials (weight dockets, receipts, etc.) should be kept on site as evidence of approved methods of disposal or recycling and must be presented to Council and/or Principal Certifying Authority upon request.
- xiv) All materials on site or being delivered to the site are to generally be contained within the site. The requirements of the Protection of the Environment Operations Act 1997 must be complied with when placing/stockpiling loose material, disposing of concrete waste, or other activities likely to pollute drains or water courses.
- xv) Any materials stored on site must be stored out of view or in such a manner so as not to cause unsightliness when viewed from nearby lands or roadways.
- xvi) Public footways, include nature strips and roadways adjacent to the site must be maintained and cleared of obstructions during construction. No building materials, waste containers or skips may be stored on the road reserve or footpath without prior separate approval from Council, including payment of relevant fees.
- xvii) Building operations such as brick-cutting, washing tools or paint brushes, and mixing mortar not be performed on the roadway or public footway or any other locations which could lead to the discharge of materials into the stormwater drainage system.
- xviii) All site waters during excavation and construction must be contained on site in an approved manner to avoid pollutants entering into waterways or Council's stormwater drainage system.
- xix) Any work must not prohibit or divert any natural overland flow of water.
- xx) Toilet facilities for employees must be provided in accordance with WorkCover NSW.

(Reason: To ensure that demolition, building and any other site works are undertaken in accordance with relevant legislation and policy and in a manner which will be non-disruptive to the local area.)

18. STORMWATER MANAGEMENT PLAN - CERTIFICATION REQUIREMENT (GC)

A detailed Stormwater Management Plan (SWMP) in line with Council's Stormwater Management Code is to be prepared and certified by a practicing Chartered Professional Engineer on the National Professional Engineer's Register (NPER) at Engineers Australia and submitted to the Principal Certifying Authority and Council, prior to the issue of a Construction Certificate. The SWMP is to be based on the approved development as modified by any conditions of consent.

(Reason: To ensure appropriate provision is made for the disposal and management of stormwater generated by the development, and to ensure public infrastructure in Council's care and control is not overloaded.)

19. SYDNEY WATER - STAMPED PLANS PRIOR TO COMMENCEMENT (GC)

The approved plans must be submitted to a Sydney Water Quick Check agent or Customer Centre to determine whether the development will affect Sydney Water's sewer and water mains, stormwater drains and/or easements, and if further requirements need to be met. Plans will be appropriately stamped.

For Quick Check agent details please refer to the web site www.sydneywater.com.au (see Building Developing and Plumbing then Quick Check) or telephone 13 20 92. The consent authority or a Certifying Authority must ensure that a Quick Check agent/Sydney Water has stamped the plans before the commencement of work.

(Reason: Compliance with Sydney Water requirements.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF A CONSTRUCTION CERTIFICATE (CC)

20. BASIX COMMITMENTS (CC)

The approved BASIX Certificate shall be submitted to the Principal Certifying Authority with the application for a Construction Certificate.

Where a change or changes are proposed in the BASIX commitments, the applicant must submit a new BASIX Certificate to the Principal Certifying Authority and Council. If any proposed change in the BASIX commitments is inconsistent with the development consent the applicant will be required to submit a modification to the development consent to Council under Section 4.55 of the Environmental Planning and Assessment Act 1979.

All commitments in the BASIX Certificate must be shown on the plans and submitted to the Principal Certifying Authority, prior to the issue of ~~accompanying~~ the Construction Certificate.

(Reason: Statutory compliance.)

MODIFIED: 29 May 2020 (DA2018/115/2)

21. PRIVACY SCREEN (CC)

A privacy screen with a height no less than 1.8m from the FFL of the balcony attached to bedroom 3 must be constructed along the southern side of the balcony. Details demonstrating compliance with this condition are to be submitted to the Principal Certifying Authority, prior to issue of the Construction Certificate.

(Reason: To ensure the roof remains non-trafficable and address visual privacy.)

MODIFIED: 29 May 2020 (DA2018/115/2)

22. WINDOWS TO BE OPAQUE

The two two-storey windows on the northern elevation of the dwelling house shall have an opaque finish. Details demonstrating compliance with this condition are to be submitted to the Principal Certifying Authority, prior to issue of the Construction Certificate.

(Reason: To ensure privacy between existing and future neighbouring dwellings while maintaining solar access)

MODIFIED: 29 May 2020 (DA2018/115/2)

23. BUILDING CODE OF AUSTRALIA - COMPLIANCE WITH (CC)

All architectural drawings, specifications and related documentation shall comply with the Building Code of Australia (BCA). All work must be carried out in accordance with the requirements of the Building Code of Australia (BCA).

In the case of residential building work for which the Home Building Act 1989 requires there to be a contract of insurance in force in accordance with Part 6 of that Act, such a contract of insurance is to be in force before any building work authorised to be carried out by the consent commences.

Details demonstrating compliance with this condition are to be submitted to the Principle Certifying Authority, prior to issue of the Construction Certificate.

(Reason: This is a 'prescribed' condition under clause 98(1) of the Environmental Planning and Assessment Regulation 2000.)

24. CAR PARKING - BASEMENT CAR PARKING REQUIREMENTS (CC)

Details demonstrating compliance with the following is to be submitted to the Principal Certifying Authority, prior to issue of the Construction Certificate:

- i) Minimal internal clearance of the basement is 2.2m in accordance with BCA requirements.
- ii) Driveways shall comply with Australian/New Zealand Standard AS/NZS 2890.1:2004 - Parking facilities - Off-street car parking and achieve a maximum gradient of 1:4.
- iii) Basement entries and ramps/driveways within the property are to be no more than 3.5m wide.
- iv) Provision of pump-out systems and stormwater prevention shall be in accordance with Council's Stormwater Management Guide.

(Reason: To ensure suitable development.)

25. CAR PARKING - VEHICULAR ACCESS RAMPS (CC)

Vehicular access ramps shall comply with the provisions of AS/NZS 2890.1:2004. Plans to be submitted shall contain the following details:

- i) Longitudinal section along the extreme wheel paths of each driveway/access ramp at a scale of 1:25 demonstrating compliance with the scraping provisions of AS/NZS 2890.1:2004. It shall include all levels and grades, including those levels stipulated as boundary levels, both existing and proposed. It shall extend from the centre-line of the roadway through to the parking area.

- ii) Sections showing the clearance to the underside of any overhead structure (minimum headroom requirements 2200mm minimum for standard headroom clearance or 2400mm where disabled access provisions are to be provided) demonstrating compliance with the provisions of AS/NZS 2890.1:2004.
- iii) Longitudinal section along the gutter line showing how it is intended to transition the vehicular crossing into the existing kerb and gutter. Boundary levels shall generally run parallel with the kerb levels.
- iv) Location of verge trees, street furniture and service installations.
- v) Superimposition of vehicle turning circles for access into parking spaces.
- vi) Certification that the design complies with AS/NZS 2890.1:2004 by a Qualified Engineer.

The certification referred to in (vi) above shall be submitted to the Principal Certifying Authority prior to the issue of a Construction Certificate (for the design) and to the Principal Certifying Authority prior to the issue of any Occupation Certificate for the 'as-built works'.

(Reason: To ensure adequate vehicular access can be achieved.)

26. CAR PARKING - COMPLIANCE WITH AS/NZS 2890.1:2004 (CC)

Car parking dimensions must comply with the Australian/New Zealand Standard AS/NZS 2890.1:2004 - Parking facilities - Off-street car parking. Details demonstrating compliance are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To ensure compliance with Australian Standards relating to parking of vehicles.)

27. COUNCIL PERMITS – FOR ALL ACTIVITIES ON COUNCIL LAND (CC)

Works Permit

(as per Section 68 of the Local Government Act 1993 and Section 138 and 139 of the Roads Act 1993)

A Works Permit is required for construction of a vehicular crossing (driveway), new stormwater down pipe connection to kerb and gutter, new footpath and/or stormwater connection. A Works Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Standing Plant Permit

This permit must be applied for where it is intended to park a concrete pump, crane or other plant on the roadway or footpath. A Standing Plant Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Skip Bin Permit

This permit must be applied for if you intend to place a skip bin on the roadway or footpath. A Skip Bin Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Temporary Full or Part Road Closure Permit

This permit must be applied for if you require a full or a part road closure to take place to assist in your construction works. Please use the Works Permit Application Form, which is available from Council's Customer Service Centre or can be downloaded from Council's

website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Hoarding/Fencing Permit

This permit must be applied for if you intend to erect a Class A (fence type) or Class B (overhead type) hoarding/fencing along the street frontage(s). A Hoarding Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Work Zone Permit

This permit must be applied for if you require permanent parking along the kerbside at the front of the site during construction works. A Work Zone Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Ground Anchoring Permit

This permit must be applied for, for the installation of ground anchors under Council's footway/road reserve. It does not cover ground anchors under private properties. A separate approval is required to be obtained from Roads and Maritime Services (RMS) if it is proposed to install ground anchors under a State or Classified Regional Road (please refer to the end of this application form for more information).

(Reason: Council requirement.)

28. DILAPIDATION REPORT - PRE-COMMENCEMENT (CC)

Subject to access being granted, a pre-commencement Dilapidation Report is to be undertaken on all adjoining properties, which in the opinion of a suitably qualified engineer, could be potentially affected by the construction of the project. The Dilapidation Report shall be carried out prior to the issue of a Construction Certificate.

The Dilapidation Report is to be prepared by a suitably Qualified Engineer with current Corporate Membership with the Institution of Engineers, Australia or Geotechnical Practitioner. The report shall include a photographic survey of adjoining properties detailing the physical condition of those properties, both internally and externally, including walls, ceilings, roof, structural members and other such items.

If access for undertaking the dilapidation survey is denied by an adjoining owner, the applicant must demonstrate, in writing, to Council's satisfaction attempts have been made to obtain access and/or advise the affected property owner of the reason for the survey and these attempts have been unsuccessful. Written concurrence must be obtained from Council in such circumstances.

The Report shall cover structural and geotechnical factors likely to arise from the development. A copy of this Report shall be submitted to Council as a record. The person having the benefit of the development consent must, at their own cost, rectify any damage caused to other properties during the construction of the project.

(Reason: To ensure no damage to adjoining properties occurs.)

29. COMMENCEMENT OF WORKS (NO WORKS UNTIL A CC IS OBTAINED)

Building work, demolition or excavation must not be carried out until a Construction Certificate has been issued by either Strathfield Council or a Principal Certifying Authority.

Demolition of any part of a building triggers 'commencement of erection of building' pursuant of section 4.19 of the EP&A Act 1979. Accordingly, demolition works must not commence until a Construction Certificate has been issued, a Principal Certifying Authority has been appointed and a Notice of Commencement has been issued.

(Reason: To ensure compliance with statutory provisions.)

30. CAR PARKING - VEHICULAR CROSSING WIDTH AT PROPERTY BOUNDARY (CC)

Vehicular crossings are to have a maximum width of 3m at the property boundary. Details demonstrating compliance are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

The vehicular crossing (and all associated excavation works) must not be constructed closer than 2 metres from a retained protected street tree.

(Reason: Compliance with SCDCP 2005.)

31. CAR PARKING - VEHICULAR CIRCULATION, AISLE AND RAMP WIDTHS (CC)

The aisle widths, internal circulation, ramp widths and grades of the car park shall comply with the Roads and Traffic Authority Guidelines and ASNZS 2890.1:2004 - Off-Street Car Parking Code.

Vehicular manoeuvring paths are to be prepared demonstrating that all vehicles can enter or depart the site in a forward direction without encroaching on required car parking spaces.

(Reason: To ensure compliance with Australian Standards relating to manoeuvring, access and parking of vehicles.)

32. EXCAVATION - AFFECTING ADJOINING LAND (CC)

If an excavation associated with the approved development extends below the level of the base of the footings of a building on an adjoining allotment of land, the person having the benefit of the development consent must, at the person's own expense, comply with the requirements of clause 98E of the Environmental Planning and Assessment Regulation 2000, including:

- i) Protect and support the adjoining premises from possible damage from the excavation, and
- ii) Where necessary, underpin the adjoining premises to prevent any such damage.

The condition referred to in subclause (i) does not apply if the person having the benefit of the development consent owns the adjoining land or the owner of the adjoining land has given consent in writing to that condition not applying. Details shall be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Structural safety.)

33. EROSION AND SEDIMENTATION CONTROL PLAN (CC)

An Erosion and Sediment Control Plan is to be prepared where construction or excavation activity requires the disturbance of the soil surface and existing vegetation. Details including drawings and specifications must provide adequate measures for erosion and sediment control to ensure:

- i) Compliance with the approved Soil and Water Management Plan.
- ii) Removal or disturbance of vegetation and top soil is confined to within 3m of the approved building area (no trees to be removed without approval).
- iii) All uncontaminated run-off is diverted around cleared or disturbed areas.
- iv) Silt fences or other devices are installed to prevent sediment and other debris escaping from the cleared or disturbed areas into drainage systems or waterways.
- v) All erosion and sediment controls are fully maintained for the duration of demolition/development works.
- vi) Controls are put into place to prevent tracking of sediment by vehicles onto adjoining roadways.
- vii) All disturbed areas are rendered erosion-resistant by turfing, mulching, paving or similar.
- viii) All water pumped or otherwise removed from excavations or basement areas is filtered to achieve suspended solids/non filterable residue levels complying with the Australian Water Quality guidelines for Fresh and Marine Waters.
- ix) Pumped or overland flows of water are discharged so as not to cause, permit or allow erosion before the commencement of work (and until issue of the occupation certificate).

Details of the proposed soil erosion and sedimentation controls are to be submitted to the Principal Certifying Authority with the Construction Certificate Application. Under no circumstances are any works to commence, prior to these details being approved by the Principal Certifying Authority and the controls being in place on the site.

(Reason: Environmental protection.)

34. PRIVACY - OBSCURE GLAZING IN WET AREAS (CC)

All bathroom, ensuite and toilet windows shall be installed with obscure glazing. Plans shall be notated accordingly and details demonstrating compliance submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Privacy amenity.)

35. FLOODING - COMPLY WITH FLOOD IMPACT REPORT (CC)

The applicant shall comply with the flood recommendations provided in the Flood Impact Statement and the Engineering Statement – Flooding Issues prepared by TAA Consulting Engineers dated 25 July 2018 and 25 September 2018. A certificate from a suitably qualified Engineer shall be submitted to the Certifying Authority stating compliance with these recommendations, prior to the issue of a Construction Certificate.

(Reason: To mitigate flood risk and associated damage.)

36. SECTION 7.11 CONTRIBUTION PAYMENT - INDIRECT CONTRIBUTIONS PLAN) (CC)

In accordance with the provisions of Section 7.11 of the Environmental Planning and Assessment Act 1979 and the Strathfield Indirect Development Contributions Plan 2010-2030, a contribution in the form of cash, cheque or credit card (financial transaction fee applies) shall be paid to Council for the following purposes:

Local Amenity Improvement Levy	\$14,636.75
---------------------------------------	--------------------

The total amount of the contribution is valid as at the date of determination and is subject to quarterly indexation. The amount of the contribution under this condition shall be indexed in accordance with clause 4.12 of the Strathfield Indirect Development Contributions Plan

2010-2030.

Contributions must be receipted by Council and submitted to the Accredited Certifier, prior to the issue of any Construction Certificate.

A copy of this condition is to be presented to Council's Customer Service Centre when paying the contribution so that it can be recalculated.

Note: A copy of Strathfield Council's Section 7.11 Indirect Development Contributions Plan may be downloaded from Council's website.

(Reason: To enable the provision of public amenities and services required/anticipated as a consequence of increased demand resulting from the development.)

37. STORMWATER - RAINWATER RE-USE (CC)

A rainwater re-use system shall be provided in accordance with either the BASIX minimum requirements, any relevant Council Rainwater Policy and/or specification of the management of stormwater, whichever is applicable. A detailed stormwater plan showing the proposed re-use system shall be submitted to and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Compliance and amenity.)

38. STORMWATER DRAINAGE (CC)

The following stormwater precautions are required to be provided on the site:

- i) Grated drains shall be provided along the driveway/basement entry at the vehicular crossing(s) and are to connect to the internal drainage system.
- ii) Overflow paths shall be provided to allow for flows in excess of the capacity of the pipe/drainage system draining the site.
- iii) Allowance shall be made for surface runoff from adjacent properties, and to retain existing surface flow path systems through the site. Any redirection or treatment of these flows shall not adversely affect any other properties
- iv) Boundary fencing shall be erected in such a manner as not to interfere with the natural flow of ground and surface water to the detriment of any other party.

(Reason: To ensure the site is drained appropriately and does not interfere with the natural flow of flood waters.)

39. TRAFFIC - CONSTRUCTION TRAFFIC MANAGEMENT PLAN (CC)

A Construction Traffic Management Plan (CTMP) is to be prepared by an appropriately qualified Traffic Management Consultant and submitted to and approved by Council's Engineering Section, prior to the commencement of any works including demolition.

The following matters should be addressed in the CTMP (where applicable):

- i) description of the demolition, excavation and construction works;
- ii) site plan/s showing the site, roads, footpaths, site access points and vehicular movements;
- iii) size, type and estimated number of vehicular movements (including removal of excavated materials, delivery of materials and concrete to the site);
- iv) proposed route(s) from the arterial (state) road network to the site and the proposed route from the site back to the arterial road network;

- v) impacts of the work and vehicular movements on the road network, traffic and pedestrians and proposed methods to safely manage pedestrians and construction related vehicles in the frontage roadways;
- vi) any Traffic Control Plans (TCP's) proposed to regulate traffic and pedestrian movements for construction activities (such as concrete pours, crane installation/removal etc.);
- vii) proposed hours of construction related activities and vehicular movements to and from the site;
- viii) current/proposed approvals from other Agencies and Authorities (including Roads and Maritime Services, Police and State Transit Authority);
- ix) any activities proposed to be located or impact upon Council's road, footways or any public place;
- x) measures to maintain public safety and convenience;
- xi) any proposed road and/or footpath closures;
- xii) turning areas within the site for construction and spoil removal vehicles, allowing a forward egress for all construction vehicles on the site;
- xiii) locations of work zones (where it is not possible for loading/unloading to occur on the site) in the frontage roadways accompanied by supporting documentation that such work zones have been approved by the Local Traffic Committee and Council;
- xiv) location of any proposed crane and concrete pump and truck standing areas on and off the site (and relevant approvals from Council for plant on road);
- xv) a dedicated unloading and loading point within the site for all construction vehicles, plant and deliveries;
- xvi) material, plant and spoil bin storage areas within the site, where all materials are to be dropped off and collected;
- xvii) on-site parking area for employees, tradespersons and construction vehicles as far as possible;
- xviii) proposed areas within the site to be used for the storage of excavated material, construction materials and waste and recycling containers during the construction period; and
- xix) how it is proposed to ensure that soil/excavated material is not transported onto surrounding footpaths and roadways.

(Reason: To mitigate traffic impacts on the surrounding area during the construction period.)

CONDITIONS TO BE SATISFIED PRIOR TO THE COMMENCEMENT OF WORKS (CW)

40. APPOINTMENT OF A PRINCIPAL CERTIFYING AUTHORITY (PCA) (CW)

No work shall commence in connection with this Development Consent until:

- i) A construction certificate for the building work has been issued by the consent authority or a Principal Certifying Authority.
- ii) The person having the benefit of the development consent has appointed a principal certifying authority for the building work, and notified the principal certifying authority that the person will carry out the building work as an owner/builder, if that is the case.
- iii) The principal certifying authority has, no later than 2 days before the building work commences:
 - notified the Council of his or her appointment, and
 - notified the person having the benefit of the development consent of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- iv) The person having the benefit of the development consent, if not carrying out the work as an owner-builder, has:

- appointed a principal contractor for the building work who must be the holder of a contractor licence if any residential building work is involved;
 - notified the principal certifying authority of such appointment; and
 - unless that person is the principal contractor, notified the principal contractor of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- v) The person having the person having the benefit of the development consent has given at least 2 days' notice to the Council of the person's intention to commence the erection of the building.

Note: If the principal certifying authority is the Council, the nomination will be subject to the payment of a fee for the service to cover the cost of undertaking all necessary inspections and the issue of the appropriate certificates.

Under the Environment Planning and Assessment (Quality of Construction) Act, 2003, a sign must be erected in a prominent position on the work site showing the name, address and telephone number of the principal certifying authority; the name of the principal contractor (if any) for the building work and a telephone number at which that person may be contacted outside working hours. That sign must also state that unauthorised entry is prohibited. The sign must not be removed until all work has been completed.

(Reason: Statutory requirement.)

41. NOTICE OF COMMENCEMENT (CW)

No work shall commence until the following details are submitted to Council:

- i) A Notice of Commencement (form will be attached with issue of a Construction Certificate or available from our website) within two (2) days of the date on which it is proposed to commence works associated with the Development Consent;
- ii) Details of the appointment of a Principal Certifying Authority (either Council or another Principal Certifying Authority); and
- iii) Details of the name, address and licence details of the Builder.

(Reason: Statutory requirement.)

CONDITIONS TO BE SATISFIED DURING DEMOLITION AND BUILDING WORKS (DW)

42. PUBLIC INFRASTRUCTURE AND SERVICES (DW)

The applicant must comply with the requirements (including financial costs) of any relevant utility provider (e.g. Energy Australia, Sydney Water, Telstra, RMS, Council etc.) in relation to any connections, works, repairs, relocation, replacements and/or adjustments to public infrastructure or services affected by the development.

(Reason: To maintain public infrastructure and/or services.)

43. OBSTRUCTION OF PUBLIC WAY NOT PERMITTED DURING WORKS (DW)

The public way must not be obstructed by any materials, vehicles, refuse, skips or the like, under any circumstances, without the prior approval of Council.

(Reason: To maintain public access and safety.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF AN OCCUPATION CERTIFICATE (OC)

44. RAINWATER TANKS (OC)

Rainwater tanks must be installed on residential properties by a suitably qualified and licensed plumber and in accordance with the following:

- i) Australian/New Zealand Standard AS/NZS 3500:2003;
- ii) NSW Code of Practice Plumbing and Drainage, 2006 produced by Committee on Uniformity of Plumbing and Drainage Regulations in NSW (CUPDR); and
- iii) Council's rainwater tank policy.

Details demonstrating compliance with this condition are to be submitted to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To protect public health and amenity.)

45. SWIMMING POOLS / SPAS - REGISTRATION AND REQUIREMENTS (OC)

The approved swimming pool/spa must comply with all relevant legislation including:

- i) Swimming Pools Amendment Act 1992 (as amended);
- ii) Swimming Pools Regulations 2008; and
- iii) Australian Standard AS1926.1-2012 – Safety Barriers for Swimming Pools.

Swimming pool owners must register their swimming pool or spa on the NSW Swimming Pool Register. A copy of a valid certificate of compliance or relevant occupation certificate must be attached to new residential tenancy agreements to rent property with a swimming pool or spa pool. Note: This requirement does not apply to a lot in strata or community title schemes with more than two lots.

A copy of a valid certificate of compliance or relevant occupation certificate must be attached to new residential tenancy agreements to rent property with a swimming pool or spa pool. Note: This requirement does not apply to a lot in strata or community title schemes with more than two lots; or for any off the plan contacts.

Details demonstrating compliance with this condition shall be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: Safety and statutory compliance.)

46. STORMWATER - CERTIFICATION OF THE CONSTRUCTED DRAINAGE SYSTEM (OC)

The constructed stormwater system shall be certified by a suitably qualified person, in accordance with Council's Stormwater Management Code, prior to the issue of any Occupation Certificate.

(Reason: Adequate stormwater management.)

47. ENGINEERING WORKS (CERTIFICATION OF)

Prior to occupation of the premises, a Work As Executed (WAE) Plan of all engineering and/or drainage works is to be submitted to the Principal Certifying Authority. The WAE Plan is to be certified by a suitably Qualified Engineer, with Corporate Membership standing in the Institution of Engineers Australia and registered on the National Professional Engineers Register (NPER) under the appropriate professional category, demonstrating that:

- i) The stormwater drainage system; and/or
- ii) The car parking arrangement and area; and/or
- iii) Any related footpath crossing works; and/or
- iv) The proposed basement pump and well system; and/or
- v) The proposed driveway and layback; and/or
- vi) Any other civil works

Have been constructed in accordance with the approved plans and any relevant Standards and Council policies/specifications.

For major works, such as subdivisions, works within the road reserve (requiring separate S138 approval) and as where specified by Council, a Part 4A Certificate will be required. It is strongly recommended that an Engineer supervise all engineering related works.

Where Council is not the Principal Certifying Authority, an electronic copy of the above documents is to be provided to Council, prior to the issue of any Occupation Certificate.

(Reason: Asset management.)

48. CAR PARKING - SURPLUS VEHICULAR CROSSINGS (OC)

All surplus vehicular crossings and/or kerb laybacks must be removed and reinstated with concrete kerb and gutter or to the existing edging profile as specified by Council. The nature strip is to be restored and the footpath area reinstated. All of the above are to be restored to the satisfaction of Council's Engineer and at full cost to the applicant, prior to the issue of any Occupation Certificate.

(Reason: Maintenance of public infrastructure.)

49. SETBACKS FROM SIDE BOUNDARIES

The basement level shall be setback a minimum of 1550mm from each side boundary.

RESOLUTION

The application be **DEFERRED** to remove the void area on the first floor above the rumpus room and replace with a lowered ceiling and roof as the void area is considered to be excessive and unnecessary; adding to the bulk and visual appearance of the dwelling.

FOR: S. Clements, K. Lindeberg, G. Andonoski

AGAINST: Nil

**** End Minutes - Report No. 3****